


LOCATION OF WATER WELL		Fraction	Section Number	Township Number	Range Number
County: Stafford		SW 1/4 SE 1/4 NE 1/4	26	T 22 S	R 12 E/W
Distance and direction from nearest town or city? 10 miles North of Stafford, KS		Street address of well if located within city?			
WATER WELL OWNER: Kenneth Scheufler		Board of Agriculture, Division of Water Resources			
Well #, St. Address, Box #: 619 North Weiland		Application Number: Not Required			
City, State, ZIP Code: Ellinwood, KS 67526					
DEPTH OF COMPLETED WELL: 60 ft. Bore Hole Diameter 9 in. to 60 ft. and 60 in. to 60 ft.					
All Water to be used as:					
1 Domestic		3 Feedlot		5 Public water supply	
2 Irrigation		4 Industrial		6 Oil field water supply	
		7 Lawn and garden only		8 Air conditioning	
		10 Observation well		9 Dewatering	
				11 Injection well	
				12 Other (Specify below)	
				STOCK	
Well's static water level: 26 ft. below land surface measured on 9 month 15 day 1980 year					
Pump Test Data: Well water was 26 ft. after 9 hours pumping 15 gpm					
Yield NOT CK'D gpm: Well water was 26 ft. after 9 hours pumping 15 gpm					
TYPE OF BLANK CASING USED:					
1 Steel		3 RMP (SR)		5 Wrought iron	
2 PVC		4 ABS		6 Asbestos-Cement	
				7 Fiberglass	
				8 Concrete tile	
				9 Other (specify below)	
				Casing Joints: Glued ☒ Clamped ☐	
				Welded ☐	
				Threaded ☐	
Blank casing dia: 5 in. to 50 ft. Dia 50 in. to 50 ft. Dia 50 in. to 50 ft.					
Casing height above land surface: 12 in., weight 1.5 lbs./ft. Wall thickness or gauge No. 200					
TYPE OF SCREEN OR PERFORATION MATERIAL:					
1 Steel		3 Stainless steel		5 Fiberglass	
2 Brass		4 Galvanized steel		6 Concrete tile	
				7 PVC	
				8 RMP (SR)	
				9 ABS	
				10 Asbestos-cement	
				11 Other (specify)	
				12 None used (open hole)	
Screen or Perforation Openings Are:					
1 Continuous slot		3 Mill slot		5 Gauzed wrapped	
2 Louvered shutter		4 Key punched		6 Wire wrapped	
				7 Torch cut	
				8 Saw cut	
				9 Drilled holes	
				11 None (open hole)	
Screen-Perforation Dia: 5 in. to 60 ft. Dia 60 in. to 60 ft. Dia 60 in. to 60 ft.					
Screen-Perforated Intervals: From 50 ft. to 60 ft. From 50 ft. to 60 ft. From 50 ft. to 60 ft.					
Interval Pack Intervals: From 40 ft. to 60 ft. From 40 ft. to 60 ft. From 40 ft. to 60 ft.					
Annular Fill: From 25 ft. to 40 ft. From 25 ft. to 40 ft. From 25 ft. to 40 ft.					
GROUT MATERIAL:					
1 Neat cement		2 Cement grout		3 Bentonite	
4 Other				5 Other	
Grouted Intervals: From 0 ft. to 10 ft. From 21 ft. to 21 ft. From 21 ft. to 21 ft.					
What is the nearest source of possible contamination:					
1 Septic tank		4 Cess pool		7 Sewage lagoon	
2 Sewer lines		5 Seepage pit		8 Feed yard	
3 Lateral lines		6 Pit privy		9 Livestock pens	
				10 Fuel storage	
				11 Fertilizer storage	
				12 Insecticide storage	
				13 Watertight sewer lines	
				14 Abandoned water well	
				15 Oil well/Gas well	
				16 Other (specify below)	
				PASTURE LAND	
Direction from well: All Directions How many feet ? Water Well Disinfected? Yes ☒ No ☐					
Is a chemical/bacteriological sample submitted to Department? Yes ☐ No ☒ If yes, date sample 18 month 18 day 1980 year					
Pumps submitted: 18 month 18 day 1980 year Pump Installed? Yes ☐ No ☒					
Pump Manufacturer's name: CLARKE WELL & Eq., Inc. Model No. HP Volts Volts					
Depth of Pump Intake: 26 ft. Pumps Capacity rated at 18 gal./min.					
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other					
CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on 9 month 15 day 1980 year					
Is this record true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 185					
This Water Well Record was completed on 9 month 18 day 1980 year under the business name of CLARKE WELL & Eq., Inc. by (signature) CLARKE					
LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM TO		LITHOLOGIC LOG	
		0 10		Fine sand, topsoil & sand & gravel & cemented sand	
		10 13		Brown sandy clay	
		13 30		Sand & sandy green clay	
		30 44		Sand & sandy brown clay	
		44 46		Sand & gravel, fine to very fine	
		46 50		Brown clay	
		50 60		Sand & gravel, fine	
ELEVATION: UNKNOWN					
Depth(s) Groundwater Encountered 1. 26 ft. 2. 26 ft. 3. 26 ft. 4. 26 ft. (Use a second sheet if needed)					
INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.					

OFFICE USE ONLY

T

22

R

12

E

SEC.

26

SW 1/4 SE 1/4 NE 1/4