

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	Count: <u>Stafford</u>	Fraction: <u>SW 1/4 SE 1/4 SE 1/4</u>	Section number: <u>29</u>	Township number: <u>T 22</u>	Range number: <u>R 12 E 20</u>
2. Distance and direction from nearest town or city: <u>Hudson Kans.</u>			3. Owner of well: <u>Steve Martling</u>		
Street address of well location if in city: <u>1 Block West 1 blk North Postoffice</u>			R.R. or street: <u>Hudson Kansas</u>		
4. Locate with "X" in section below:			6. Bore hole dia. <u>5</u> in. Completion date <u>6-8-76</u>		
<div style="text-align: center;"> </div>			Well depth <u>105</u> ft.		
			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <input type="checkbox"/> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u>746</u> lbs./ft. Dia. <u>2</u> in. to <u>105</u> ft. depth Wall Thickness: inches or Dia. <u>2</u> in. to <u>105</u> ft. depth gage No. <u>154</u>		
5. Type and color of material			10. Screen: Manufacturer's name <u>ROVAL JET</u>		
			Type <u> </u> Dia. <u>2 1/2</u> in.		
			Slot/gauze <u>1/32</u> Length <u>28</u> in.		
			Set between <u>100</u> ft. and <u>104</u> ft.		
			Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>4 to 10</u>		
			11. Static water level: <u>16</u> ft. below land surface Date <u>6-6-76</u>		
			12. Pumping level below land surfaces: <u>20</u> ft. after <u>1</u> hrs. pumping <u>60</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u> </u> g.p.m.		
			13. Water sample submitted: <u> </u> mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date <u>6-8-76</u>		
			14. Well head completion: <u> </u> Pitless adapter <u>12</u> inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>6</u> ft. to <u>16</u> ft.		
			16. Nearest source of possible contamination: ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <input checked="" type="checkbox"/> Not installed		
			Manufacturer's name <u> </u>		
			Model number <u> </u> HP <u> </u> Volts <u> </u>		
			Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m.		
			Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)					
18. Elevation: <u>1890</u>		19. Remarks: <u>Owner Hoatys pump Centrifugal for house use. domestic</u>		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Steve Martling</u> Business name <u> </u> License No. <u>123</u> Address <u> </u> Signed <u>Charles J. Martling</u> Date <u>6-8-76</u> Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5