

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well: County Stafford		Fraction <i>NE/SE</i> 1/4 1/4 1/4		Section number 14		Township number 22		Range number 14	
2. Distance and direction from nearest town or city: <i>1 1/4 mi SW West into field Seward, Ks</i> Street address of well location if in city:					3. Owner of well: Dave Marmie R.R. or street: 4210 Falcon City, state, zip code: Great Bend, Ks. 67530				
4. Locate with "X" in section below: Sketch map: 				6. Bore hole dia. <u>29</u> in. Completion date <u>9-30-76</u> Well depth <u>129</u> ft.					
5. Type and color of material				From	To	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
						8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
				9. Casing: Material <u>steel</u> ; Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>18</u> in. RMP <u>16</u> PVC <input type="checkbox"/> Weight <u> </u> lbs./ft. Dia. <u>16</u> in. to <u>129</u> ft. depth Wall Thickness: <u> </u> inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u> </u>					
Top Soil				0	3	10. Screen: Manufacturer's name <u>R/B</u> Type <u>steel</u> Dia. <u>16</u> Slot/gauge <u>3/16</u> Length <u>60</u> Set between <u>89</u> ft. and <u>129</u> ft. <input type="checkbox"/> Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/2 3/4 3/8</u>			
Brown Clay				3	23	11. Static water level: <u> </u> mo./day/yr. <u>11</u> ft. below land surface Date <u>7-14-76</u>			
Light Gray Clay				23	30	12. Pumping level below land surfaces: <u>12</u> ft. after <u>1</u> hrs. pumping <u>1000</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>1200</u> g.p.m.			
Light Gray Brown & Yellow Clay Sand Mixed				30	53	13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date <u>7-14-76</u> <u> </u> mo./day/yr.			
Sand and Gravel Med. Coarse				53	63	14. Well head completion: <input type="checkbox"/> Pitless adapter <u> </u> inches above grade			
Light Yellow Clay				63	64	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neap cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete <u> </u> Depth: From <u> </u> ft. to <u>10</u> ft.			
Sand and Gravel				64	109	16. Nearest source of possible contamination: ft. <u>12</u> Direction <u>west</u> Type <u>septic tank</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No			
Sand and Gravel Some Gray Clay				109	117	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>W.L.R.</u> Model number <u>3CM12</u> HP <u>40</u> Volts <u> </u> Length of drop pipe <u>85</u> ft. capacity <u>800</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
Sand and Gravel				117	131				
Blue Gray Shale				131	135				
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Rosencrantz-Bemis</u> <u>134</u> Business name License No. Address <u>Great Bend, Ks.</u> Signed <u>Freda Aderson</u> Date <u>10/22/76</u> Authorized representative					

T
R
Sec
1/4
1/4
1/4
1/4
E
C
SE
14
14
14
14
14
14

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5