


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Stafford		Fraction C/NE 1/4 1/4		Section number 14		Township number 22 T S R		Range number 14 E W							
2. Distance and direction from nearest town or city: 1 E 2 S 1/4 E 1/4 S of Seward Street address of well location if in city:				3. Owner of well: Doug McMeill R.R. or street: 2311 Lincoln St. City, state, zip code: Great Bend, Ks. 67530											
4. Locate with "X" in section below: N W E S 1 Mile				Sketch map: 		6. Bore hole dia. 29 in. Completion date _____ Well depth 148 ft. 9-30-76									
5. Type and color of material				From		To		7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary							
Sandy Top Soil				0		8		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other							
Brown Clay				8		42		9. Casing: Material steel Height: Above or below _____ Threaded _____ Welded <input checked="" type="checkbox"/> Surface 18 in. RMP _____ PVC _____ Weight _____ lbs./ft. Dia. 16 in. to 148 ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth gage No. 7							
Brown White & Yellow Clay				42		72		10. Screen: Manufacturer's name _____ Type steel Dia. 16 Slot/size 3/16 Length 60 Set between 88 ft. and 148 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2 3/4 3/8							
Sand and Gravel Med. Coarse				72		153		11. Static water level: _____ mo./day/yr. 24 ft. below land surface Date 7-14-76							
Blue Gray shale				153		155		12. Pumping level below land surfaces: 26 ft. after 1 hrs. pumping 1200 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1400+ g.p.m.							
								13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 7-14-76							
								14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade							
								15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete IMC Depth: From 0 ft. to 10 ft.							
								16. Nearest source of possible contamination: ft. 3/4 Direction NE Type septic tank Well disinfected upon completion? _____ Yes _____ No							
								17. Pump: _____ Not installed Manufacturer's name W.L.R. Model number E76603 HP 40 Volts _____ Length of drop pipe 85 ft. capacity 1200 p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other							
								(Use a second sheet if needed)							
18. Elevation:		19. Remarks:								20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name _____ License No. _____ Address Great Bend, Ks. Signed Fredia Hodson Date 11/23/76 Authorized representative					
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley															

221414
1/4 1/4 1/4
CNE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5