


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Stafford	Fraction NE 1/4 NE 1/4 NE 1/4	Section number 24	Township number T 22 S R 14	Range number 14	EW		
2. Distance and direction from nearest town or city: 3 1/2 miles Southwest of Seward, KS Street address of well location if in city:			3. Owner of well: Ronnie DeVore R.R. or street: Route 1 City, state, zip code: St. John, KS 67576					
4. Locate with "X" in section below: N  W E S 1 Mile			Sketch map:			6. Bore hole dia. <u>5</u> in. Completion date <u>6-8-77</u> Well depth <u>60</u> ft.		
5. Type and color of material			From		To			
			Top soil & fine sand		0		11	
			Clay		11		16	
			Fine sand & clay streaks		16		26	
			Clay		26		35	
			Fine sand		35		41	
			Clay		46		48	
Sand & gravel		48		60 38				
(Use a second sheet if needed)			10' - ^{ALSO} 2" plastic					
			10. Screen: Manufacturer's name <u>Peerless Plastics</u> Type <u>PVC 160</u> Dia. <u>2"</u> Slot/gauze <u>1/8</u> Length <u>8'</u> Set between <u>52</u> ft. and <u>60</u> ft. Gravel pack? <u>yes</u> Size range of material <u>3/8-200</u>					
			11. Static water level: <u>21</u> ft. below land surface Date <u>6-8-77</u>					
			12. Pumping level below land surfaces: <u>N/checked</u> <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u> </u> g.p.m.					
			13. Water sample submitted: <u> </u> mo./day/yr. <u> </u> Yes <u>X</u> No Date <u> </u>					
			14. Well head completion: <u> </u> Pitless adapter <u>12</u> Inches above grade					
			15. Well grouted? <u>yes</u> With: <u>X</u> Neat cement <u> </u> Bentonite <u> </u> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.					
			16. Nearest source of possible contamination: <u>FIELD</u> ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <u>X</u> Yes <u> </u> No					
			17. Pump: <u>Not installed</u> Manufacturer's name <u>Clayton Mark & Co.</u> Model number <u>450</u> HP <u> </u> Volts <u> </u> Length of drop pipe <u>42</u> ft. capacity <u> </u> g.p.m. Type: <u>2" x 10" brass cylinder</u> <u> </u> Submersible <u> </u> Turbine <u> </u> Jet <u>X</u> Reciprocating <u> </u> Centrifugal <u> </u> Other					
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Clarke Well & Eq., Inc. 185 Business name License No. Address <u>Great Bend, KS 67530</u> Signed <u>[Signature]</u> Date <u>6-9-77</u> Authorized representative					
18. Elevation:		19. Remarks:						
Topography: <u> </u> Hill <u> </u> Slope <u> </u> Upland <u> </u> Valley								

22 140 24
T
R
M
Sec
1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5