WATER WELL RECORD KSA 82a-1201-1215

010

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County	Fraction		Section number		Township number	Range number		
	Pawnee	SW 1/4 NW 1/4 D	W 1/4	7	3	T 22 s	R 15	E.(A)	
2. Distance and direction from nearest town or city: 63 - E 14 - 5 H Nauned, KS. Street address of well location if in city:				street: Rt. 2 tate, zip code: Larned. Ks. 67550					
4. Locate with "X" in section below: Sketch map:						6. Bore hole dig. 29 in. Well depth 200 ft.	Completion date	<u>-</u>	
						7Cable tool X RotaryDrivenDugHollow rodJettedBoredReverse rotary 8. Use:DomesticPublic supplyIndustryX IrrigationAir conditioningStock			
S 1 Mile ————————————————————————————————————						Lawn Oil field water Other 9. Casing: Material ST.EE Height: Above or below Threaded Welded X Surface 12 in. RMP PVC Weight Ibs./ft. Dia. 16in. to 200, depth Wall Thickness; inches or			
5. Sand polor of	p so11			From	2⁵	Dia in. to ft. dept	- I - I - I - I - I - I - I - I - I - I		
Brown clay				2	8	10. Screen: Manufacturer's name			
Gray cla	y			8	15	Type steel Slot/g ag e 3/16	_ Dia16 _ Length48		
Sandy br	rown clay	·		15	23	Set between 152	.ft. and <u>200</u>	ft.	
Sand and gravel				23	30	Gravel pack? X Size range of material 3/4-3/8			
Brown & white clay with fine sand				30	44	11. Static water level: mo./day/yr.			
Sand and gravel				44	54	ft. below land surf		<u>20−7</u> 5	
Brown & gray clay				54	60	12. Pumping level below land 23 ft. after 1 h)a.p.m.	
Sand and gravel				60	73	ft. after hrs. pumping g.p.m.			
Brown cla				73	73	\$13. Water sample submitted: mo./day/yr.			
Sand and gravel				73±		X Yes No Date _ 2-20-76			
Blue clay					96	14. Well head completion: Pitless adapter	Inches above	grade	
				96	107	15. Well grouted?X			
Sand and gravel clean coarse loose				107	117	With: Neat cement Bentonite Concrete			
Blue clay				117	119	/ · · · · · · · · · · · · · · · · · · ·			
Fine sand and gravel						16. Negrest source of possible contamination: ft. 2 ml Direction 30 utn Type 2 cm steeld			
Sand and gravel medium				135	140	Well disinfected upon completed 17. Pump:		 № +-	
Sand and gravel clean coarse loose				140	197	Manufacturer's name	W L R	460°	
Shale				197	200		of tr. capocity 10		
						Type: Submersible	<u>v</u> Turbine		
	(Use a second s	neet if needed)				Jet Centrifugal	Recipro	1 1	
18. Elevation: 1975	19. Remarks: 170	8		I		20. Water well contractor's con	ertification: jurisdiction and this	report K	
Topography:						is true to the best of my knowl		34 \$ \$	
Hill Stone						Business name		nea Na	
Slope Upland Valley						Address BOX Signed Authorized repr	RE2 Date	619 19 2	