

USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Pawnee	Fraction C SW 1/4 1/4 1/4	Section number 6	Township number T 22	Range number S R 15		E/W
2. Distance and direction from nearest town or city: 4 1/2 E of Larned on K19 N side of Rd. Street address of well location if in city:			3. Owner of well: Mick Marlett R.R. or street: Rt. 2 City, state, zip code: Larned, KS				
4. Locate with "X" in section below: <div style="text-align: center;">N W E S 1 Mile</div>			Sketch map: <div style="text-align: center;">NW NE SE 1 Mile</div>				
5. Type and color of material			From	To	6. Bore hole dia. 29 in. Completion date _____ Well depth 95 ft. 6-29-76		
Top Soil			0	3	7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Brown Black Clay			3	17	8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other <input type="checkbox"/>		
Sand Gravel			17	33	9. Casing: Material Steel Height: Above or below _____ Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 16 in. to 95 ft. depth Well Thickness: inches or _____ Dia. _____ in. to _____ ft. depth Gauge No. 7		
Yellow Clay			33	34 1/2	10. Screen: Manufacturer's name Daeris Type Steel Dia. 16 Slot/gauge 3/16 Length 45 Set between 55 ft. and 95 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material _____		
Sand Gravel			34 1/2	53	11. Static water level: _____ mo./day/yr. 18 ft. below land surface Date 6-1-76		
White Clay			53	61	12. Pumping level below land surfaces: 14 ft. after 1 hrs. pumping 1000 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1100 g.p.m.		
Sand Gravel			61	87	13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 6-1-76		
White Brown			87	95	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade		
Yellow Clay			95		15. Well grouted? <input checked="" type="checkbox"/> With: Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete <input checked="" type="checkbox"/> Depth: From 0 ft. to 10 ft.		
					16. Nearest source of possible contamination: ft. 18 Direction NW Type Cornell Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
					17. Pump: _____ Not installed Manufacturer's name WLR Model number S-CHC-12 HP 60 Volts 460 Length of drop pipe 70 ft. capacity 700 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:			(Use a second sheet if needed)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencranz - Bemis 134 Business name License No. _____ Address Great Bend KS 67530 Signed Fredia Nelson Date 9/30/76 Authorized representative		
19. Remarks:							

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

M1-1023