

1 LOCATION OF WATER WELL		Fraction		Section Number		Township Number		Range Number	
County: Pawnee		SE 1/4 SE 1/4 NE 1/4		6		T 22 S		R 15 EW	
Distance and direction from nearest town or city? 4 miles east & 1/2 mile south of Larned, KS				Street address of well if located within city?					
2 WATER WELL OWNER:		H. Lee Turner							
RR#, St. Address, Box # :		Route 1							
City, State, ZIP Code :		Great Bend, KS 67530							
		Board of Agriculture, Division of Water Resources Application Number: not available							
3 DEPTH OF COMPLETED WELL		86 ft. Bore Hole Diameter 24 in. to 86 ft. and in. to ft.							
Well Water to be used as:		5 Public water supply 8 Air conditioning 11 Injection well							
1 Domestic 3 Feedlot		6 Oil field water supply 9 Dewatering 12 Other (Specify below)							
2 Irrigation 4 Industrial		7 Lawn and garden only 10 Observation well							
Well's static water level		21 1/2 ft. below land surface measured on 6 month 2 day 1981 year							
Pump Test Data		Well water was ft. after hours pumping gpm							
Est. Yield not ck'd gpm		Well water was ft. after hours pumping gpm							
4 TYPE OF BLANK CASING USED:		5 Wrought iron 8 Concrete tile Casing Joints: Glued Clamped							
1 Steel 3 RMP (SR)		6 Asbestos-Cement 9 Other (specify below) Welded XX							
2 PVC 4 ABS		7 Fiberglass Threaded							
Blank casing dia 16 in. to 46 ft. Dia in. to ft. Dia in. to ft.									
Casing height above land surface 12 in. weight 31.75 lbs./ft. Wall thickness or gauge No 188									
TYPE OF SCREEN OR PERFORATION MATERIAL:		7 PVC 10 Asbestos-cement							
1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 11 Other (specify)									
2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole)									
Screen or Perforation Openings Are:		5 Gauzed wrapped 8 Saw cut 11 None (open hole)							
1 Continuous slot 3 Mill slot 6 Wire wrapped 9 Drilled holes									
2 Louvered shutter 4 Key punched 7 Torch cut 10 Other (specify) Doerr Bridge Slot									
Screen-Perforation Dia 16 in. to 86 ft. Dia in. to ft. Dia in. to ft.									
Screen-Perforated Intervals: From 46 ft. to 86 ft. From ft. to ft. From ft. to ft.									
Gravel Pack Intervals: From 10 ft. to 86 ft. From ft. to ft. From ft. to ft.									
5 GROUT MATERIAL:		1 Neat cement 2 Cement grout 3 Bentonite 4 Other							
Grouted Intervals: From 0 ft. to 10 ft. From ft. to ft. From ft. to ft.									
What is the nearest source of possible contamination:		10 Fuel storage 14 Abandoned water well							
1 Septic tank 4 Cess pool 7 Sewage lagoon 11 Fertilizer storage 15 Oil well/Gas well									
2 Sewer lines 5 Seepage pit 8 Feed yard 12 Insecticide storage 16 Other (specify below)									
3 Lateral lines 6 Pit privy 9 Livestock pens 13 Watertight sewer lines FIELD									
Direction from well all How many feet n/a ? Water Well Disinfected? Yes No XX									
Was a chemical/bacteriological sample submitted to Department? Yes No XX If yes, date sample was submitted month day year Pump Installed? Yes X 6-4-81 No									
If Yes: Pump Manufacturer's name Peerless Pump Co. Model No. 12LB-2 HP 60 Volts									
Depth of Pump Intake 70 ft. Pumps Capacity rated at 900 gal./min.									
Type of pump:		1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other							
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on 6 month 2 day 1981 year and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 185 This Water Well Record was completed on 6 month 20 day 1981 year under the business name of Clarke Well & Eq., Inc. by (signature)									
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:									
		FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG		
		0	5	Topsoil, sandy tan clay	76	85	Fine & med. sand & gravel		
		5	15	Sandy tan clay w/fine sand and gravel	85	86	Brown clay		
		15	23	Sandy tan clay w/caliche					
		23	54	Fine & med. sand & gravel					
		54	57	Tan clay w/med. & coarse gravel					
		57	64	Med. sand & gravel					
		64	72	Sandy yellow & tan clay					
		72	74	Fine & med. sand & gravel					
		74	76	Tan clay, sand & gravel					
ELEVATION: unknown									
Depth(s) Groundwater Encountered 1. 21.5 ft. 2. ft. 3. ft. 4. ft.		(Use a second sheet if needed)							
INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.									