

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

County Pawnee		Fraction X NW NE NE ne 1/4 ne 1/4 nw 1/4		Section number 33 33		Township number T 22 S		Range number R 15	
1. Location of well: 2-N 6-E 1-N 3/4-E from Zook, Ks. Street address of well location if in city:				3. Owner of well: Milford & Zook R.R. or street: Rt. 2 City, state, zip code: Larned, Kansas 67550					
2. Distance and direction from nearest town or city:				3. Owner of well:		6. Bore hole dia. 29 in. Completion date 12-16-78 Well depth 50 ft.			
7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		9. Casing: Material steel Height: Above or xxx Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 15 in. to 50 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. 7			
10. Screen: Manufacturer's name Johnson Type steel Dia. <input type="checkbox"/> Slot xxx 3/16 Length 10 Set between 40 ft. and 50 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/4 3/8				11. Static water level: <input type="checkbox"/> mo./day/yr. 26 ft. below land surface Date 5-22-76		12. Pumping level below land surfaces: 33 ft. after 1 hrs. pumping 200 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 500 g.p.m.			
13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 5-22-76				14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
16. Nearest source of possible contamination: ft. 700 Direction SW Type gaswell Well disinfected upon completion? hth Yes <input type="checkbox"/> No				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		18. Elevation:			
19. Remarks:				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name License No. Address Great Bend, Ks. 67530 Signed Sandy Kilgore Date 12-26 Authorized representative					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5