

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Pawnee	Fraction C 1/4 SW 1/4 NE 1/4	Section number 6	Township number T 22	Range number S R 11e EW
2. Distance and direction from nearest town or city: 6 mi. W. of Harrod, Ks. Street address of well location if in city:			3. Owner of well: Dale Otte R.R. or street: RR #3 City, state, zip code: Harrod, Ks.		
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		6. Bore hole dia. 10 in. Completion date _____ Well depth 25 ft. 3-22-77	
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Top Soil		0	2	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Clay		2	7	9. Casing: Material pvc Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 60160 lbs./ft. Dia. 6 in. to 25 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 1280	
Blue Clay & Gravel		7	10	10. Screens: Manufacturer's name Johnson Type steel Dia. 6 Slot/gauge _____ Length 10 Set between 15 ft. and 25 ft. _____ ft. and 1/2 3/4 3/8 ft.	
Sand & Gravel		10	23	11. Static water level: _____ mo./day/yr. 9 ft. below land surface Date 3-22-77	
Fire Clay		23	25	12. Pumping level below land surfaces: NA _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
<i>At farmers requests we set 10' Johnson perf.</i>				13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 3-22-77	
				14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade	
				15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 20 ft. 10	
				16. Nearest source of possible contamination: fr. W Direction N Type septic tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name Great Bend, Ks. 67530 License No. Address _____ Signed Fredia Dodson Date 3/28/77 Authorized representative	
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5