

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well: County <u>Pawnee</u>		Fraction <u>N 2 1/4 E</u> 1/4 1/4 1/4		Section number <u>20</u>	Township number <u>T 22 S</u>	Range number <u>R 16 E/W</u>
2. Distance and direction from nearest town or city: <u>2 South - West side of rd. of Larned.</u> Street address of well location if in city:				3. Owner of well: <u>Dale Zook</u> R.R. or street: <u>Rt. 2</u> City, state, zip code: <u>Larned, Ks.</u>		
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map:		6. Bore hole dia. <u>2 1/2</u> in. Completion date <u>5-5-76</u> Well depth <u>55</u> ft.		
		7. Cable tool <u>Rotary</u> Driven <u>Dug</u> Hollow rod <u>Jetted</u> Bored <u>Reverse rotary</u>		8. Use: Domestic <u>Public supply</u> Industry <u>Irrigation</u> Air conditioning <u>Stock</u> Lawn <u>Oil field water</u> Other		
		9. Casing: Material <u>steel</u> Height: <u>Above or below</u> Threaded <u>Welded</u> Surface <u>1 1/2</u> in. RMP <u>PVC</u> Weight <u>16</u> lbs./ft. Dia. <u>16</u> in. to <u>55</u> ft. depth Wall Thickness: inches or Dia. <u>16</u> in. to <u>55</u> ft. depth gage No. <u>7</u>		10. Screen: Manufacturer's name <u>Roers</u> Type <u>steel</u> Dia. <u>16</u> Slot/gauge <u>3/16</u> Length <u>25</u> Set between <u>35</u> ft. and <u>55</u> ft. Gravel pack? <u>Size range of material 1/2 3/4 1/2</u>		
		11. Static water level: <u>17</u> ft. below land surface Date <u>12-21-75</u>		12. Pumping level below land surfaces: <u>19</u> ft. after <u>1</u> hrs. pumping <u>500</u> g.p.m. <u>   </u> ft. after <u>   </u> hrs. pumping <u>   </u> g.p.m. Estimated maximum yield <u>500</u> g.p.m.		
		13. Water sample submitted: <u>Yes</u> No Date <u>1-6-76</u>		14. Well head completion: <u>   </u> Pitless adapter <u>   </u> Inches above grade		
5. Type and color of material		From	To	15. Well grouted? <u>Yes</u> With: <u>Neat cement</u> Bentonite <u>Concrete</u> Depth: From <u>0</u> ft. to <u>10</u> ft.		
<u>Top Soil</u>		<u>0</u>	<u>1</u>	16. Nearest source of possible contamination: ft. <u>1 1/2</u> Direction <u>N</u> Type <u>Correl</u> Well disinfected upon completion? <u>Yes</u> <u>No</u>		
<u>Clay</u>		<u>1</u>	<u>7</u>	17. Pump: Manufacturer's name <u>WLR</u> Not installed Model number <u>5-CM-12</u> HP <u>60</u> Volts <u>   </u> Length of drop pipe <u>45</u> ft. capacity <u>500</u> g.p.m. Type: <u>Submersible</u> <u>Turbine</u> <u>Jet</u> <u>Reciprocating</u> <u>Centrifugal</u> <u>Other</u>		
<u>Sandy Clay</u>		<u>7</u>	<u>18</u>	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Rosenkrantz - Bernis 134</u> Business name <u>Great Bend, Ks.</u> License No. <u>   </u> Address <u>   </u> Signed <u>Fredia Norborn</u> Date <u>9/3/76</u> Authorized representative		
<u>Sand</u>		<u>18</u>	<u>27</u>			
<u>Clay</u>		<u>27</u>	<u>28</u>			
<u>Good Gravel</u>		<u>28</u>	<u>40</u>			
<u>Good Sand &amp; Gravel</u>		<u>40</u>	<u>55</u>			
<u>Clay</u>		<u>55</u>	<u>89</u>			
<u>Sand</u>		<u>89</u>	<u>91</u>			
<u>Blue Clay</u>		<u>91</u>	<u>115</u>			
<u>Fire Clay</u>		<u>115</u>				
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:				
Topography: <u>   </u> Hill <u>   </u> Slope <u>   </u> Upland <u>   </u> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5