

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Pawnee	Fraction SE 1/4 ne 1/4 SW 1/4	Section number 26	Township number T 22	Range number S R 17	EW
2. Distance and direction from nearest town or city: 3s-4w-3/4 west into field Street address of well location if in city: <u>from Larned, Ks.</u>				3. Owner of well: Dale Josefiak R.R. or street: Rozel, Ks. 67574 City, state, zip code:			
4. Locate with "X" in section below: Sketch map: 5-S 3 1/2-W from Larned, Ks.				6. Bore hole dia. 29 in. Completion date Well depth 78 ft. 3-30-76			
5. Type and color of material				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
				9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 16 in. to 78 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 7			
				10. Screen: Manufacturer's name Doerres Type steel Dia. 16 Slot/gauze 3/16 Length 40 Set between 38 ft. and 78 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/4-3/8-1/2			
				11. Static water level: 11 ft. below land surface Date 6-18-75			
				12. Pumping level below land surfaces: 36 ft. after 1 hrs. pumping 800 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1000 g.p.m.			
13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 6-18-75				14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade			
15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.				16. Nearest source of possible contamination: ft. 1/2 mile Direction north Type corrall Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
17. Pump: Manufacturer's name W.L.R. Not installed Model number 5-12cm HP 40 Volts 460 Length of drop pipe 60 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name License No. Address Great Bend, Ks. 67530 Signed S. Kilgore Date 6-19-76 Authorized representative			
18. Elevation:		19. Remarks:					
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley							

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5