


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Pawnee	Fraction SW 1/4 SW 1/4 SW 1/4	Section number 2	Township number T 22 S	Range number R 18W E/W
2. Distance and direction from nearest town or city: 1s 3e Street address of well location if in city: Sandford, Ks.			3. Owner of well: Marion Roesler R.R. or street: R3 Larned, Ks. 67550 City, state, zip code:		
4. Locate with "X" in section below: 			Sketch map:		
5. Type and color of material			From	To	6. Bore hole dia. 8 in. Completion date 3-30-78 Well depth 140 ft.
Top Soil-Clay			0	35	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Fine Sand-Clay			35	55	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Clay			55	80	9. Casing: Material <input type="checkbox"/> Height: Above <input checked="" type="checkbox"/> Below <input type="checkbox"/> Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2.8 lbs./ft. Dia. 5 in. to 140 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. sch 40
Sand			80	100	10. Screen: Manufacturer's name Jetstream Type pvc Dia. 5" Slot/gauze 1/32" Length 20' Set between 120 ft. and 140 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8-3/4"
Clay			100	110	11. Static water level: <input type="checkbox"/> ma./day/yr. 38 ft. below land surface Date 3-30-78
Sand-Gravel			110	140	12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 50 g.p.m.
					13. Water sample submitted: ____ ma./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____
					14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter ____ inches above grade
					15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 14 ft.
					16. Nearest source of possible contamination: ft. 75 Direction e Type sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Valts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Kellys Waterwell Ser 186 Business name R2 Great Bend, Ks. License No. ____ Address Kelly Price Date 9-18-79 Signed Kelly Price Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Farm WWC-5