


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Pawnee	Fraction NE NW NE 1/4 1/4 1/4	Section number 6	Township number T 22 S	Range number R 38 E/W		
2. Distance and direction from nearest town or city: 1 1/2 MI. East 1 MI. South of Rozel Street address of well location if in city:			3. Owner of well: Ed Webster R.R. or street: City, state, zip code: Rozel, Kansas 67574					
4. Locate with "X" in section below: 			Sketch map:		6. Bore hole dia. 6 in. Completion date 27 Well depth 99 ft. Oct 1977			
5. Type and color of material			From	To	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			Brown clay		0	16	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
			Fine dark sand		16	22	9. Casing: Material <input type="checkbox"/> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 14 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft.	
			Good sand very little clay		22	75	Dia. 5 in. to 89 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 200	
			Blue clay		75	78	10. Screen: Manufacturer's name Sold by PW Type PVC Dia. 5 Slot/gauze 1/16 Length 10 Set between 89 ft. and 99 ft. ft. and <input type="checkbox"/> ft.	
			Good coarse clean sand and gravel		78	100	Gravel pack? yes Size range of material 4	
							11. Static water level: <input type="checkbox"/> mo./day/yr. 32 ft. below land surface Date 10 27 77	
							12. Pumping level below land surfaces: 34 ft. after 40 hrs. pumping 15 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 100 plus g.p.m.	
							13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>	
							14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 14 inches above grade	
					15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 15 ft.			
					16. Nearest source of possible contamination: septic ft. 15 Direction SW Type + Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
					17. Pump: Not installed Manufacturer's name WELA Model number EDP-650 HP 1/2 Volts 115 Length of drop pipe 63 ft. capacity 9 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
18. Elevation:			19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Dean Waterhouse Drlg. 243 Business name Dean Waterhouse License No. 11-5-77 Address Hanston, Kansas Signed Dean Waterhouse Date 11-5-77 Authorized representative			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5