

1 LOCATION OF WATER WELL		Fraction	Section Number	Township Number	Range Number
County: Pawnee		1/4 cse 1/4 ne 1/4	# 7	T 22 S	R 19w EW
Distance and direction from nearest town or city? 2w 2 1/2 s Rozel, Ks.			Street address of well if located within city?		
2 WATER WELL OWNER: RR#, St. Address, Box # : City, State, ZIP Code :			James Snodgrass Rozel, Ks. 67574 Board of Agriculture, Division of Water Resources Application Number: NONE		
3 DEPTH OF COMPLETED WELL 168 ft. Bore Hole Diameter 8 in. to 168 ft., and in. to ft. Well Water to be used as: 1 Domestic 3 Feedlot 5 Public water supply 8 Air conditioning 11 Injection well 2 Irrigation 4 Industrial 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 7 Lawn and garden only 10 Observation well Well's static water level 70 ft. below land surface measured on 10 month 24 day 78 year Pump Test Data : Well water was ft. after hours pumping gpm Est. Yield 40 gpm: Well water was ft. after hours pumping gpm					
4 TYPE OF BLANK CASING USED: 1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile Casing Joints: Glued Clamped 2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded Blank casing dia 5 in. to 128 ft., Dia 12 in. weight 2.8 lbs./ft. Wall thickness or gauge No sch 40 Casing height above land surface 12 in. weight 2.8 lbs./ft. Wall thickness or gauge No sch 40 TYPE OF SCREEN OR PERFORATION MATERIAL: 1 Steel 3 Stainless steel 5 Fiberglass 7 PVC 10 Asbestos-cement 2 Brass 4 Galvanized steel 6 Concrete tile 8 RMP (SR) 11 Other (specify) Screen or Perforation Openings Are: 1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole) 2 Louvered shutter 4 Key punched 7 Torch cut 9 Drilled holes 12 None used (open hole) Screen-Perforation Dia 5 in. to ft., Dia in. to ft., Dia in to ft. Screen-Perforated Intervals: From 128 ft. to 168 ft., From ft. to ft. to ft. to ft. Gravel Pack Intervals: From 14 ft. to 168 ft., From ft. to ft. to ft. to ft.					
5 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other Grouted Intervals: From 4 ft. to 14 ft., From ft. to ft. to ft. to ft. What is the nearest source of possible contamination: 1 Septic tank 4 Cess pool 7 Sewage lagoon 10 Fuel storage 14 Abandoned water well 2 Sewer lines 5 Seepage pit 8 Feed yard 11 Fertilizer storage 15 Oil well/Gas well 3 Lateral lines 6 Pit privy 9 Livestock pens 12 Insecticide storage 16 Other (specify below) Direction from well SW How many feet 80 ? Water Well Disinfected? Yes No Was a chemical/bacteriological sample submitted to Department? Yes No If yes, date sample was submitted month day year Pump Installed? Yes No If Yes: Pump Manufacturer's name Goulds Model No. em HP 1 Volts 230 Depth of Pump Intake 150 ft. Pumps Capacity rated at 15 gal./min. Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other					
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on 10 month 24 day 78 year and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 186 This Water Well Record was completed on 2 month 14 day 80 year under the business name of Kellys Waterwell Serv by signature Kelly Price					
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM TO LITHOLOGIC LOG FROM TO LITHOLOGIC LOG			
		0 115 Top Soil-Clay			
		115 168 Sandrocks			
ELEVATION: unknown					
Depth(s) Groundwater Encountered 1. 115 ft. 2. ft. 3. ft. 4. ft.		(Use a second sheet if needed)			
INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.					