

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County PAWNEE	Fraction SE 1/4 SW 1/4 SW 1/4	Section number 24	Township number T 22	Range number S R 19 E/W
2. Distance and direction from nearest town or city: 5 south & 2-1/2 miles east of ROZEL, KS.			3. Owner of well: DAN COLGLAZIER			
Street address of well location if in city:			City, state, zip code: ROZEL, KANSAS 67574			
4. Locate with "X" in section below:			Sketch map:		6. Bore hole dia. <u>8</u> in. Completion date <u>11/10/80</u> Well depth <u>62</u> ft.	
					7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
					8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
5. Type and color of material			From To		9. Casing: Material <input type="checkbox"/> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>18</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. <u>5</u> in. to <u>42</u> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <u>200 plus</u>	
					10. Screen: Manufacturer's name <u>jet stream</u> Type <u>PVC</u> Dia. <u>5"</u> Slot/gauze <u>.040</u> Length <u>20'</u> Set between <u>42</u> ft. and <u>62</u> ft. Grovel pack? <u>yes</u> Size range of material <u>#1</u>	
					11. Static water level: <u>36</u> ft. below land surface Date <u>11/10/80</u>	
					12. Pumping level below land surfaces: <u>50</u> ft. after <u>2</u> hrs. pumping <u>10</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>15-18</u> g.p.m.	
					13. Water sample submitted: <u> </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>	
					14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u>18</u> Inches above grade	
					15. Well grouted? <u>yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>-3</u> ft. to <u>-15</u> ft.	
					16. Nearest source of possible contamination: ft. <u>20</u> Direction <u>SW</u> Type <u>stock tank</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: <u> </u> Not installed Manufacturer's name <u>REDA</u> Model number <u>9D9P050</u> HP <u>1/2</u> Volts <u>115</u> Length of drop pipe <u>57'</u> ft. capacity <u>9</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. DEAN WATERHOUSE DRILLING Business name <u>HANSTON, KS, 67849</u> License No. <u> </u> Address <u> </u> Signed <u>Dean Waterhouse</u> Date <u>11/10/80</u> Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5