


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

To Leonard 1-25-78

1. Location of well:	County Harvey	Fraction NE 1/4 SW 1/4 SE 1/4	Section number 10	Township number T 22 S	Range number R 2	NEW
2. Distance and direction from nearest town or city: 6 miles West of Newton Street address of well location if in city:			3. Owner of well: City of Hesston Hesston, Kansas City, state, zip code:			
4. Locate with "X" in section below: Sketch map: Well No. 12 Approx. 1000' N. of Well No. 8			6. Bore hole dia. 30 in. Completion date 4/2/76 Well depth 136 ft.			
			7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
			8. Use: Domestic <input type="checkbox"/> Public supply <input checked="" type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other <input type="checkbox"/>			
5. Type and color of material			9. Casing: Material Stl Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 36 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 63 lbs./ft. Dia. 16 in. to 11 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 375			
			10. Screen: Manufacturer's name Layne & Bowler, Inc. Type St. Steel Dia. 16" Slot/gauze .105 Length 25' Set between 111 ft. and 136 ft. Gravel pack? yes Size range of material 1/8x1/2			
			11. Static water level: 36' 1" below land surface Date 3/31/76			
			12. Pumping level below land surfaces: 108 ft. after 8 hrs. pumping 350 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 350 g.p.m.			
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>			
			14. Well head completion: Pitless adapter 36 inches above grade			
			15. Well grouted? yes With: Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete <input type="checkbox"/> Depth: From 0 ft. to 20 ft.			
			16. Nearest source of possible contamination: ft. 500 Direction West Type Home Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
			17. Pump: Not installed Manufacturer's name Layne Model number 10RKN HP 40 Volts 440 Length of drop pipe 120 ft. capacity 350 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
18. Elevation:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne Western Co 102 Business name License No. Address Wichita, Kansas Signed [Signature] Date 4/2/76 Authorized representative			
19. Remarks: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						