

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County HARVEY	Fraction SE 1/4 SE 1/4 SW 1/4	Section number 12	Township number T 22 S	Range number R 2 E
2. Distance and direction from nearest town or city: 3 1/4 mile West of Hesston			3. Owner of well: Steve Koufman R.R. or street: R.R. #1 City, state, zip code: Moundridge, KNS 67		
4. Locate with "X" in section below:			Sketch map:		
			6. Bore hole dia. 12 in. Completion date _____ Well depth 90 ft.		
			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material PVC Height: Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 12" in. RMP _____ PVC <input checked="" type="checkbox"/> Weight 3.22 lbs./ft. Dia. 6 in. to 90 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 255		
5. Type and color of material			From	To	10. Screen: Manufacturer's name Cent-tech - own slot
top loam			0	5	Type PVC Dia. 6"
brown clay			5	20	Slot/gauze .064 Length 15'
deep stone			20	23	Set between 60 ft. and 75' ft.
brown clay			23	60	Gravel pack? <input checked="" type="checkbox"/> Size range of material 70-44
SAND & clay mixed			60	75	11. Static water level: _____ mo./day/yr. 30 ft. below land surface Date 2/12/76
brown grey clay			75	88	12. Pumping level below land surfaces: 60 ft. after 1 hrs. pumping 15 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 15-20 g.p.m.
Shale grey to dark			88	90	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____
					14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter _____ inches above grade
					15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 10 ft. to 0 ft.
					16. Nearest source of possible contamination: ft. 120 Direction EAST Type SEPTIC Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: _____ Not installed Manufacturer's name VALLEY #S1208-F Model number _____ HP 1/2 Volts 230 Length of drop pipe 60 ft. capacity 12 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. PAUL'S INC 175 Business name License No. Address Box 26 Hesston, KNS Signed Paul B. Smith Date 3/4/75 Authorized representative
18. Elevation:			19. Remarks:		
Topography: <input checked="" type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					