## WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

	County	Fraction				Township number Range number											
1. Location of well:	Harvey NW 1/4 NW 1/4 NE		1/4				r 2W	<b>₽</b>									
	tion from nearest town or city:	215 14	1	er of well		ohn Dyck											
				or street: RR#1 state, zip code: Mondridge , Kansas													
4. Locate with "X" in section below: Sketch map:						6. Bore hole dia. 11 in. Completion date											
N Skerch map.						Well depth 105 ft. 7-6-77											
						7Cable tool X_ Rotary Driven Dug											
						Hollow rod Jetted Bored Reverse rotary  8. Use: Domestic Public supply Industry											
w   i   i   E						Irrigation Air conditioning Stock											
sw se i																	
									I → I Mile → I				Τ_		Dia in. to 105ft. dep Dia in. to ft. dep	th!Wall Thickness: inc	ches or
									5. Type and color of material				From	То	10. Screen: Manufacturer's r	name	
Topsoil				0	3	Styrene											
					1	Slot/gduze/ .06 Length 15'											
Clay				3	38	Set between 90 ft. and 105 ft.											
Fine Sand				38	43	Gravel pack? Ves. Size range of material 2-1/8"											
Clay				43	60	11. Static water level: mo./day/yr. 50 ft. below land surface Date 7-6-77											
Clay							<del>-//-</del>										
Fine Sand				60	64	12. Pumping level below land		. g.p.m.									
Clay				64	85	ft. after Estimated maximum yield	, , -										
Fine Sand				85	98	13. Water sample submitted:		_g.p.m. /day/yr.									
						Yes No											
Gray Shale				98_	105	14. Well head completion: Pitless adapter	10	arade									
						15. Well grouted?Yes	to2 fine sa	nd mix.									
						With: Neat cement Depth: From40!! ft. to	Bentonite X	Concrete J									
						16. Nearest source of possible											
						ft Direction	Туре										
						Well disinfected upon completion? X Yes No											
						17. Pump:  Manufacturer's name	X Not installed	~}									
							Model number         HP Volts           Length of drop pipe         ft. capacity g.p.m.										
				+		Length of drop pipe ———— Type:	it. capacity	-g.p.m.									
		. 10-1			<u> </u>	Submersible	Turbine										
	(Use a second	sheet if needed)				Jet Centrifugal	Recipro	Scaring Sec.									
18. Elevation:	19. Remarks: Septic System was not installed when					20. Water well contractor's											
	the well was drilled.					This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.											
Topography:	graphy:					Harp Well & Pump 236  Business name License No. Address Wichita, Kansas											
X Slope	No apparent source for contamination.																
Upland		Signed Sm. Orn	Old Date														
Valley						Authorized re	Form WW	3-77									