



USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Harvey	Fraction NW 1/4 NW 1/4	Section number 18	Township number T 22 S	Range number R 2W E 10
2. Distance and direction from nearest town or city:		3. Owner of well:		Kenneth Stucky		
Street address of well location if in city:		R.R. or street:		RFD		
		City, state, zip code:		Burrton, Kansas 67020		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 6 in. Completion date 11/3/78 Well depth 100 ft.		
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top soil		0	3	9. Casing: Material Plastic Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft.		
Clay		3	44	Dia. 3 in. to 80 ft. depth Wall Thickness: inches or Dia. 6 in. to 80 ft. depth gage No. 100		
Fine sand		44	45	10. Screen: Manufacturer's name Certain feed Type sawed Dia. 3 Slot/gauze 1/4 Length 20 Set between 80 ft. and 100 ft. ft. and 100 ft.		
Fine sand w/clay		45	53	Gravel pack? yes Size range of material 1/4 x 1/4		
Med. sand w/little clay		53	54	11. Static water level: 30 ft. below land surface Date 11-3-78 mo./day/yr.		
Med. sand		54	66	12. Pumping level below land surfaces: 36 ft. after 1 hrs. pumping 100 g.p.m. ft. after 1 hrs. pumping 100 g.p.m. Estimated maximum yield 200 g.p.m.		
Clay		66	83	13. Water sample submitted: yes mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date 11-3-78		
Clay w/sand		83	86	14. Well head completion: Pitless adapter 8 inches above grade		
Med. sand w/very little clay		86	98	15. Well grouted? yes With: Neat cement Bentonite <input type="checkbox"/> Concrete <input type="checkbox"/> Depth: From 0 ft. to 10 ft.		
Shale		98	100	16. Nearest source of possible contamination: ft. Direction none Type none Well disinfected upon completion? yes Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		
(Use a second sheet if needed)				17. Pump: x Not installed Manufacturer's name Not installed Model number Not installed HP Not installed Volts Not installed Length of drop pipe Not installed ft. capacity Not installed g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report Rosenhartz-Bent's Ent. Inc. 134 211 W. 4th Hutchinson, Kansas Business name License No. Address 211 W. 4th Hutchinson, Kansas Signed Mike Flaw Date 6-8-79 Authorized representative			