


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Harvey	Township name	Fraction NW SE	Section number 24	Town number 22S	Range number 2W
Distance and direction from nearest town or city: 3 W. 1 S.			3 Owner of well: Red Tiger Drilling Co.			
Street address of well location if in city: Nesston, Ks.			Address: 1720 Wichita Plaza Wichita, Kan.			
Locate with "X" in section below: 			Sketch map:			4 Well depth: 120 ft. Date of completion 5-8-75 Well diameter 7 in.
2 Type and color of material			From	To	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
			6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input checked="" type="checkbox"/> Oil Rig Supply			
			7 Casing: Material PVC Height: above below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. Diam. _____ Weight _____ lbs./ft. _____ 4 in. to 120 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth			
			8 Screen: Manufacturer MPI Type PVC Dia. 4 Slot/gauge 1/16" Length 40' Set between 80 ft. and 100 ft. Fittings: 1 1/8 - 3/4" Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material _____			
			9 Static water level: 45 ft. below land surface Date 5-8-75			
(use a second sheet if needed)			10 Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 30 g.p.m.		11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
			12 Well head completion: 12 <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade			
			13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 0 ft. to 10 ft.			
			14 Nearest source of possible contamination: oil ft. 101 Direction S Type Test Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
			15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Kellys Water Well Serv Business name _____ License No. _____ Address R 2 Great Bend, Kan Signed Kelly Price Date 5-10-75 Authorized representative			