


LOCATION OF WATER WELL		Fraction	Section Number	Township Number		Range Number	
County: HARVEY		NE 1/4 NE 1/4 SE 1/4	31	T 22 S		R 2 W E/W	
Distance and direction from nearest town or city? 4 N, 3 W, 1/2 N, 1/8 into field from Farmer's Corner-Hwy 50 and Halstead				Street address of well if located within city? Halstead, Ks.			
WATER WELL OWNER: Ann Conwell				Board of Agriculture, Division of Water Resources			
RR#, St. Address, Box #: 2106 N. Old Manor				Application Number:			
City, State, ZIP Code: Wichita, Ks.							
DEPTH OF COMPLETED WELL: 67 ft. Bore Hole Diameter: 30 in. to ft. and in. to ft.							
Well Water to be used as:				11 Injection well			
1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below)							
2 Irrigation 4 Industrial 7 Lawn and garden only 10 Observation well							
Well's static water level: 14.6 ft. below land surface measured on 12 month 14 day 80 year							
Pump Test Data: Well water was ft. after hours pumping gpm							
Est. Yield gpm: Well water was ft. after hours pumping gpm							
TYPE OF BLANK CASING USED:				Casing Joints: Glued <input checked="" type="checkbox"/> Clamped <input checked="" type="checkbox"/>			
1 Steel 3 RMP (SR) 6 Asbestos-Cement 9 Other (specify below) Welded							
2 PVC 4 ABS 7 Fiberglass TRANSITE Threaded							
Blank casing dia: 1.6 in. to 4.4 ft. Dia in. to ft. Dia in. to ft.							
Casing height above land surface: 12 in. weight 37 lbs./ft. Wall thickness or gauge No 3/4"							
TYPE OF SCREEN OR PERFORATION MATERIAL:				10 Asbestos-cement TRANSITE			
1 Steel JOHNSON Stainless steel 5 Fiberglass 8 RMP (SR) 11 Other (specify)							
2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole)							
Screen or Perforation Openings Are:				8 Saw cut TRANSITE 11 None (open hole)			
1 Continuous slot 3 Mill slot 6 Wire wrapped JOHNSON 9 Drilled holes							
2 Louvered shutter 4 Key punched 7 Torch cut 10 Other (specify)							
Screen-Perforation Dia: 1.6 in. to 6.7 ft. Dia in. to ft. Dia in. to ft.							
Screen-Perforated Intervals: From 4.4 ft. to 5.7 TRANSITE ft. From ft. to ft.							
From 5.7 ft. to 6.7 JOHNSON ft. From ft. to ft.							
Gravel Pack Intervals: From 1.0 ft. to 6.7 ft. From ft. to ft.							
From ft. to ft. From ft. to ft.							
5 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other							
Grouted Intervals: From 0 ft. to 10 ft. From ft. to ft. From ft. to ft.							
What is the nearest source of possible contamination:				10 Fuel storage 14 Abandoned water well			
1 Septic tank 4 Cess pool 7 Sewage lagoon 11 Fertilizer storage 15 Oil well/Gas well							
2 Sewer lines 5 Seepage pit 8 Feed yard 12 Insecticide storage 16 Other (specify below)							
3 Lateral lines 6 Pit privy 9 Livestock pens 13 Watertight sewer lines NONE APPARENT							
Direction from well: How many feet? Water Well Disinfected? Yes <input checked="" type="checkbox"/> No							
Was a chemical/bacteriological sample submitted to Department? Yes No <input checked="" type="checkbox"/> If yes, date sample							
was submitted month day year: Pump Installed? Yes <input checked="" type="checkbox"/> No <input checked="" type="checkbox"/>							
If Yes: Pump Manufacturer's name: Valley Model No. 10HH0 HP 8.0 Randolph volts N/A							
Depth of Pump Intake: 4.5 ft. Pumps Capacity rated at 6.50 gal./min.							
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other							
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was							
completed on 12 month 14 day 79 year							
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 236							
This Water Well Record was completed on 8 month 6 day 1980 year under the business							
name of Harp Well & Pump by (signature) M. Arnold							
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
		0	8	Clay			
		8	30	Fine Sand with Clay			
		30	67	Medium to Coarse Sand and Gravel			
		67	70	Blue Shale			
ELEVATION:							
Depth(s) Groundwater Encountered 1. 14.6 ft. 2. ft. 3. ft. 4. ft.		(Use a second sheet if needed)					
INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.							