

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Harvey	Fraction NW 1/4 SW 1/4 NW 1/4	Section number 32	Township number T 22 S	Range number R 2W E/W
2. Distance and direction from nearest town or city: Street address of well location if in city: 4 North, 3 West, & 1/2 North Halstead, Ks.			3. Owner of well: Dale Wenger R.R. or street: City, state, zip code: R#2 Burrton, Kansas		
4. Locate with "X" in section below: Sketch map: <p>From the West edge of Halstead, Kans. and 50 Hyway it is 4North, 3 West and 1/2 North.</p>			6. Bore hole dia. 30 in. Completion date 9-28-77 Well depth 90 ft.		
5. Type and color of material			7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input checked="" type="checkbox"/> Reverse rotary <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material Transite Height: Above or below See #19 Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 37 lbs./ft. Dia. 16 in. to 90 ft. depth Wall Thickness: inches or 3/4 " Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 3/4 "		
			10. Screen: Manufacturer's name Johnson Type irrigator Dia. 16" Slot/gauge 100 Length 36' Set between 48-74 ft. and 74-84 ft. Gravel pack? yes Size range of material 1/4-1/8"		
			11. Static water level: 23 ft. below land surface Date 9-28-77 mo./day/yr.		
(Use a second sheet if needed)			12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.		
			13. Water sample submitted: ____ mo./day/yr. Yes ____ No ____ Date ____		
			14. Well head completion: 12 capped ____ Pitless adapter ____ Inches above grade		
			15. Well grouted? yes 1-2 fine sand mix With: ____ Neat cement ____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: ____ ft. ____ Direction ____ Type None Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ____ No		
(Use a second sheet if needed)			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: ____ Submersible ____ Turbine ____ Jet ____ Reciprocating ____ Centrifugal ____ Other		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name Wichita, Kansas License No. 67209 Address Signed M. Arnold Date 10-4-77 Authorized representative		
			18. Elevation:		
			19. Remarks: Flat Ground From #9 Banded But Joint No near apparent source for contamination.		
			Topography: ____ Hill ____ Slope ____ Upland ____ Valley		