

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County PAWNEE	Fraction SE 1/4 1/4 1/4	Section number 27	Township number T 22 S	Range number R 20 E/W
2. Distance and direction from nearest town or city: 1/2 EAST 5 1/2 S 1/4 EAST FROM Street address of well location if in city: BURDETT, KS			3. Owner of well: CLINTON SMITH R.R. or street: City, state, zip code: BURDETT KANSAS			
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 6. Bore hole dia. 8 in. Completion date 12 APRIL 77 Well depth 70 ft. 7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other 9. Casing: Material <input type="checkbox"/> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 24 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 250 LBS/ft. Dia. 5 in. to 50 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250			
5. Type and color of material			From	To		
TAN CLAY			0	10	10. Screen: Manufacturer's name STL Type RMP Dia. 5" Slot/gauze 1/16 Length 20 Set between 50 ft. and 70 ft. Gravel pack? YES Size range of material #1	
TAN SANDY - SOFT CLAY			12	55	11. Static water level: 29 ft. below land surface Date 12-17	
REP - SANDSTONE			53	56	12. Pumping level below land surfaces: 40 ft. after 3 hrs. pumping 15 g.p.m. 70 ft. after 92 hrs. pumping 25 g.p.m. Estimated maximum yield 25 g.p.m.	
BROKEN SANDSTONE + SAND			56	67	13. Water sample submitted: 6 No Date	
RAINBO CLAY			67	70	14. Well head completion: 24" Inches above grade	
BLUE SHALE			70	92	15. Well grouted? YES With: 2 Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to -12 ft.	
REP CLAY			99	100	16. Nearest source of possible contamination: STOCK TANK ft. 70 Direction EAST Type STOCK TANK Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
MULTI COLORED CLAYS			100	110	17. Pump: Not installed Manufacturer's name CLAYTON MARK Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe 42 ft. capacity 3 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input checked="" type="checkbox"/> Other	
(Use a second sheet if needed)						
18. Elevation:		19. Remarks: WELL WILL BE PUMPED WITH WINDMILL. WELL PRODUCES 60-70 MORE WATER THAN SEEMS POSSIBLE COMPARED TO MATERIAL TAKEN FROM WELL.		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Dean Water house DRIG Business name HANSTON KANSAS License No. 1/4 Address TOPEKA KANSAS Signed Dean Water house Date 5-9-77 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5