

1 LOCATION OF WATER WELL: Fraction NW 1/4 NW 1/4 NW 1/4 Section Number 26 Township Number T 22 S Range Number R 22 E  
 COUNTY: HODGEMAN

Distance and direction from nearest town or city street address of well if located within city?  
 FROM HANSTON - 1/4 SOUTH ON COUNTY ROAD

2 WATER WELL OWNER: HANN, SANDY - *Tenant House*  
 RRR, St. Address, Box #: BOX 2 Board of Agriculture, Division of Water Resources  
 City, State, ZIP code: HANSTON, KS 67849- Application Number:

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:

	X		
1	NW	NE	
H i l e	W	E	
	SW	SE	

4 DEPTH OF COMPLETED WELL 75 ELEVATION: 0  
 Depth(s) Groundwater Encountered 1. 0 ft. 2. 0 ft. 3. 0 ft.  
 WELL'S STATIC WATER LEVEL 25 ft. below land surface measured on mo/day/yr 12/12/96  
 Pump test data: Well water was 0 ft. after 0 hours pumping 0 gpm  
 Estimated Yield 45 gpm: Well water was 0 ft. after 0 hours pumping 0 gpm  
 Bore Hole Diameter 10 in. to 75 ft., and in. to 0 ft.  
 WELL WATER TO BE USED AS: DOMESTIC  
 Was a chemical/bacteriological sample submitted to department? No ;  
 If yes, mo/day/yr sample was submitted Water well disinfected? Yes

5 TYPE OF BLANK CASING USED: PVC CASING JOINTS: GLUED  
 Blank casing diameter 5 in. to 75 ft., Dia in. to 0 ft., Dia in. to 0 ft.  
 Casing height above land surface 12 in., weight 200 lbs/ft. Wall thickness or gauge No. 21  
 TYPE OF SCREEN OR PERFORATION MATERIAL: PVC  
 SCREEN OR PERFORATION OPENINGS ARE: SAW CUT

SCREEN PERFORATED INTERVALS: From 50 ft. to 70 ft., From 0 ft. to 0 ft.  
 From 0 ft. to 0 ft., From 0 ft. to 0 ft.  
 GRAVEL PACK INTERVALS: From 25 ft. to 75 ft., From 0 ft. to 0 ft.  
 From 0 ft. to 0 ft., From 0 ft. to 0 ft.

6 GROUT MATERIAL BENTONITE  
 Grout Intervals: From 0 ft. to 25 ft., From 0 ft. to 0 ft., From 0 ft. to 0 ft.  
 What is the nearest source of possible contamination: SEPTIC TANK  
 Direction from well? WEST How many feet? 110

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	30	TOPSOIL CLAY			
30	40	FINE SAND			
40	50	FINE - MED SAND			
50	60	COARSE SAND SHALL GRAVEL GRAVEL			
60	62	CLAY			
62	70	MEDIUM SAND			
70	90	MEDIUM SAND CLAY LAYERS			
90	120	GRAY CLAY			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was Constructed under my jurisdiction and was completed on (mo/day/year) 12/12/96 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 179 This Water Well Record was completed on (mo/day/yr) 12/17/96 under the business name of JOE'S WELL SERVICE, INC. by (signature) *Judith Crist*