

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

HANSTON NW

KS

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

CDD

1. Location of well:		County Hodgeman	Fraction SE 1/4 SE 1/4 SW 1/4	Section number 13	Township number T 22 S	Range number R 22 E
2. Distance and direction from nearest town or city: east of Hanston Street address of well location if in city:				3. Owner of well: Ralph Ewy R.R. or street: City, state, zip code: Hanston, Ks. 67849		
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 26 in. Completion date 7-14-77 Well depth 60 ft.	
					7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP 16 pyc Weight 31 lbs./ft. Dia. 16 in. to 40 ft. depth Wall thickness: inches or Dia. in. to ft. depth gage No. 3/16		
Topsoil		0	4	10. Screen: Manufacturer's name Doerr Metal Type Gravel Guard Dia. 16 in. <input checked="" type="checkbox"/> Slot gauze (1/16) Length 20 Set between 40 ft. and 60 ft. Gravel pack? Yes Size range of material 2-4		
Clay		4	40	11. Static water level: mo./day/yr. 34 1/2 ft. below land surface Date 7-10-77		
Sand		40	54	12. Pumping level below land surfaces: 50 ft. after 2 hrs. pumping 400 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 450 g.p.m.		
Clay		54	60	13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date		
BROCK 60'				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
34.5				15. Well grouted? YES With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 12 ft.		
25.5 sat thick				16. Nearest source of possible contamination: Fuel ft. 10 Direction E Type Tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
in Alluvium				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Western Land Roller Model number A7742 HP 20 Volts Des 1 Length of drop pipe 55 ft. capacity 400 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Knoefler Bros. Drlg. Business name License No. 130 Address Jetmore Signed Dale Knoefler Date 8-2-77 Authorized representative		
18. Elevation:		19. Remarks: Concrete slab was installed				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		2152 60 2092				
TOPO						

22 22 22 13 SE SE SW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5