

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.


110' S-10' KE

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

ADA

1 Location of well:	County HODGEMAN	Township name MARENIA	Fraction NE SE NE 1/4	Section number 53	Town number 22	Range number 22
Distance and direction from nearest town or city: 2 1/2 MILES SOUTH 1 1/2 MILES WEST 1/4 SOUTH OF HANSTON KANSAS			3 Owner of well: CURE INC Address: HANSTON KANSAS			
Locate with "X" in section below: N  W E S 1 Mile			Sketch map:			4 Well depth: 67 ft. Date of completion: 23-NOV Well diameter: 16 in.
2 Type and color of material			From	To	5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
topsoil			0	5	6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well	
light sandy clay			5	28	7 Casing: Material STEEL Weight: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 30 in. Diam. 16 in. to 41 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
GOOD CLEAN SAND			28	32	8 Screen: Manufacturer WABROWN ENTERPRISE Type STEEL Dia. 16 Slot/gauze 1/4 Length 20 Set between 41 ft. and 61 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/2 down	
STRIP OF TAN CLAY			32	35	9 Static water level: 32 ft. below land surface Date 23 NOV	
GOOD CLEAN SAND - MED-COURSE			35	59	10 Pumping level below land surfaces: 54 ft. after 4 hrs. pumping 650 g.p.m. ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 726 g.p.m.	
SHALE			59	60	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
ROCK 59'					12 Well head completion: <input type="checkbox"/> Pitless adapter 30 inches above grade	
32					13 Well grouted? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From _____ ft. to _____ ft.	
27' sat thick					14 Nearest source of possible contamination: Overseer ft. 300 Direction SE Type CREEK Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
in Alluvium					15 Pump: <input type="checkbox"/> Not installed Manufacturer's name GOULD Model number 14 HP 15 Volts 440 Length of drop pipe 60 ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(use a second sheet if needed)					17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. DEAN WATERHOUSE DRILLING 2-13 Business name _____ License No. _____ Address HANSTON KANSAS Signed Dean Waterhouse Date 15-June-75 Authorized representative	
16 Remarks: elevation						
Topography: 2172 <input type="checkbox"/> Hill 59 <input type="checkbox"/> Slope 2113' <input type="checkbox"/> Upland TOPO <input checked="" type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5