

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

Hanston KS

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

DBB

1. Location of well:		County Hodgeman	Fraction NW 1/4 NW 1/4 SE 1/4	Section number 34	Township number T 22	Range number S R 22	E 22
2. Distance and direction from nearest town or city: 2S, 1/2 W. 1/2 S Street address of well location if in city: of Hanston,				3. Owner of well: V. H. Holmes R.R. or street: City, state, zip code: Hanston, Kansas 67849			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 24 in. Completion date 9-16-76 Well depth 97 ft.			
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
				9. Casing: Material steel Height: (Above) or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 6 in. to 38 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gage No. 7 ga			
				10. Screen: Manufacturer's name Doerr Metal Type Gravel Guard Dia. 16 in Slot/gauze 3/16 Length 60 Set between 37 ft. and 97 ft. Gravel pack? Yes Size range of material 1/4 to 1/2			
				11. Static water level: _____ mo./day/yr. 27 ft. below land surface Date 6-12-76			
				12. Pumping level below land surfaces: 50 ft. after 4 hrs. pumping 1200 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1800 g.p.m.			
				13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____			
				14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> 12 Inches above grade			
				15. Well grouted? no With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From _____ ft. to _____ ft.			
				16. Nearest source of possible contamination: ft. 1200 Direction NE Type Well Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
				17. Pump: Manufacturer's name Western Land Roll Model number B76336 HP 60 Volts _____ Length of drop pipe 90 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
		(Use a second sheet if needed)					
18. Elevation:		19. Remarks:					
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		2165 70 2095 TOPO					
		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Knoefler Bros. Drilling Business name License No. 130 Address Jetmore, Signed Dale Knoefler Date 10-2-76 Authorized representative					

22 220 34 NW NW SE
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5