



USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

Hanslow KS

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

DCB

1. Location of well:	County Hodgeman	Fraction NW 1/4 SW 1/4 SE 1/4	Section number 34	Township number T 22 S	Range number R 22 E
2. Distance and direction from nearest town or city: 1 1/2 W, 3/4 S of Hanston,			3. Owner of well: V. H. Holmes		
Street address of well location if in city:			R.R. or street:		
City, state, zip code: Hanston, Kansas 67849					
4. Locate with "X" in section below: 		Sketch map: 		6. Bore hole dia. 26 in. Completion date 6-20-79 Well depth 100 ft.	
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia 16 in. to 40 ft. depth Wall Thickness: <input type="checkbox"/> inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 188	
5. Type and color of material		From	To	10. Screen: Manufacturer's name Doerr Metal	
Topsoil		0	2	Type steel Dia. 16 in	
Clay		2	34	Slat gauze (1/8) Length 60 ft	
Clay with sand st		34	39	Set between 40 ft. and 100 ft.	
Sand		39	50	Gravel pack? yes Size range of material 1/8-1/2 ft.	
Clay		(50)	56	11. Static water level: 32 ft. below land surface Date 6-1-79	
Sand fine & dark		56	70	12. Pumping level below land surfaces: 800 g.p.m.	
Clay		70	75	____ ft. after ____ hrs. pumping ____ g.p.m.	
Sand blue & fine		75	100	____ ft. after ____ hrs. pumping ____ g.p.m.	
Clay		100	105	Estimated maximum yield 1000 g.p.m.	
				13. Water sample submitted: ____ mo./day/yr.	
				Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date ____	
				14. Well head completion: 12 Inches above grade	
				____ Pitless adapter	
				15. Well grouted? yes	
				With: ____ Neat cement ____ Bentonite <input checked="" type="checkbox"/> Concrete	
				Depth: From 0 ft. to 12 ft.	
				16. Nearest source of possible contamination: 800 ft. Direction IN Type Irrig	
				Well disinfected upon completion? ____ Yes <input checked="" type="checkbox"/> No	
				17. Pump: ____ Not installed	
				Manufacturer's name Western Land	
				Model number ____ HP ____ Volts ____	
				Length of drop pipe 90 ft. capacity 750 g.p.m.	
				Type: ____ Submersible <input checked="" type="checkbox"/> Turbine	
				____ Jet ____ Reciprocating	
				____ Centrifugal ____ Other	
				(Use a second sheet if needed)	
18. Elevation:	19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley	Concrete slab to be installed by customer TOPO 2165 SPS 2115		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Knoefler Bros. Drilling Business name Jetmore, Ks License No. 130 Address Dale Knoefler Date 6-21-79 Signed Dale Knoefler Authorized representative		

22
 22
 34
 Sec
 1/4 1/4 1/4
 NUSOSE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5