

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

JETMORE
K²

AAB

1. Location of well:		County Hodgeman	Fraction NE 1/4 NE 1/4 NE 1/4 NW	Section number 36	Township number T 22 S R	Range number 24	<input checked="" type="checkbox"/> EW
2. Distance and direction from nearest town or city: Street address of well location if in city:				3. Owner of well: R.R. or street: City, state, zip code:			
4. Locote with "X" in section below:				Sketch map:		6. Bore hole dia. <u>8</u> in. Completion date <u>11-22-77</u> Well depth <u>390</u> ft.	
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
5. Type and color of material				From	To	9. Casing: Material <u>Steel</u> Height: <u>Above or below</u> Threaded <input checked="" type="checkbox"/> Welded <input type="checkbox"/> Surface <u>24</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>11</u> lbs./ft. Dia. <u>4 1/2</u> in. to <u>340</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u> </u>	
Topsoil				0	3	10. Screen: Manufacturer's name <u>Knoefler Bros.</u> Type <u>Torch</u> Dia. <u>4 1/2</u> <input checked="" type="checkbox"/> Slot gauge Length <u>50</u> Set between <u>340</u> ft. and <u>390</u> ft. ft. and <u> </u> ft. Gravel pack? <u>Yes</u> Size range of material <u>1-1/8</u>	
Brown & yellow clay				3	32	11. Static water level: <u>190</u> ft. below land surface Date <u> </u> mo./day/yr.	
Blue shale				32	205	12. Pumping level below land surfaces: <u>220</u> ft. after <u>4</u> hrs. pumping <u>15</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>30</u> g.p.m.	
White clay				205	330	13. Water sample submitted: <u> </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>	
Sand rock				330	390	14. Well head completion: <input type="checkbox"/> Pitless adapter <u>24</u> inches above grade	
<u>BRock 3' P.P.</u>						15. Well grouted? <u>Yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>30</u> ft.	
<u>CRETACEOUS WELL</u>						16. Nearest source of possible contamination: <u>stock</u> ft. <u>300</u> Direction <u>N</u> Type <u>Well</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
<u>(Use a second sheet if needed)</u>						17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Aermotor</u> Model number <u>SD12100</u> HP <u>1</u> Volts <u>230</u> Length of drop pipe <u>273</u> ft. capacity <u>15</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:	19. Remarks:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Knoefler Bros. Drilling</u> Business name <u>Jetmore, Kansas</u> License No. <u>130</u> Address <u>Dale Knoefler</u> Signed <u>Dale Knoefler</u> Date <u>12-5-77</u> Authorized representative			
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	Concrete slab was installed <u>2331</u> <u>TOPO</u>						

22 24 36 NW NE NE
T R Sec 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-3