

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County: <u>Harvey</u> Fraction: <u>NE 1/4 NE 1/4 NW 1/4</u> Section number: <u>14</u> Township number: <u>T 22 S</u> Range number: <u>R 3 E</u>	
2. Distance and direction from nearest town or city: <u>7 3/4 West?</u> Street address of well location if in city: <u>Houston Kansas on County Rd 556</u>	
3. Owner of well: <u>Frank Nachtigal</u> R.R. or street: <u>P.R.</u> City, state, zip code: <u>Moundville Kans. 67107</u>	
4. Locate with "X" in section below: <p>Sketch map: Road Septic House Drainage to S w from well</p>	
5. Type and color of material	
6. Bore hole dia. <u>8 1/2</u> in. Completion date <u>11-29-75</u> Well depth <u>91</u> ft.	
7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
9. Casing: Material <u>PLST</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <u>91</u> Surface <u>24</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u> </u> lbs./ft. Dia. <u>5</u> in. to <u>91</u> ft. depth Wall Thickness: <u> </u> inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>14</u>	
10. Screen: Manufacturer's name <u>Jet Stream</u> Type <u>PIC</u> Dia. <u>5"</u> Slot/gauze <u>1/16</u> Length <u>10 ft</u> Set between <u>81</u> ft. and <u>91</u> ft. Gravel pack? <u>yes</u> Size range of material <u>1/4-1/8"</u>	
11. Static water level: <u>26' 6"</u> ft. below land surface Date <u>11-29-75</u> mo./day/yr.	
12. Pumping level below land surfaces: <u>30</u> ft. after <u>3</u> hrs. pumping <u>15</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>50</u> g.p.m.	
13. Water sample submitted: <u> </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u>11-29-75</u>	
14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u>24</u> inches above grade	
15. Well grouted? <u>yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>5</u> ft. to <u>15</u> ft.	
16. Nearest source of possible contamination: <u>Sewer</u> ft. <u>30</u> Direction <u>S.W.</u> Type <u>Pipe</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u> </u> HP <u> </u> Volts <u> </u> Model number <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:	
19. Remarks: <u>The Contractor will pour concrete slab around well when ground settles down.</u>	
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Peterson Bros Inc</u> <u>138</u> Business name License No. Address <u>Box 150 Lindsborg Kans</u> Signed <u>Wally Peterson</u> Date <u>11-29-75</u> <u>By</u> Authorized representative	