

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.


WOLF

CCN

WATER WELL RECORD  
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County <b>Finney</b>	Township name	Fraction <b>SE<sup>1</sup>/<sub>4</sub>, SW<sup>1</sup>/<sub>4</sub></b> <b>SW<sup>1</sup>/<sub>4</sub></b>	Section number <b>31</b>	Town number <b>T22S</b>	Range number <b>R34W</b>
Distance and direction from nearest town or city: <b>8 mile N., &amp; 1 mile E., of Deerfield</b> Street address of well location if in city:			3 Owner of well: <b>H2O Ranch</b> <b>% Bob Landon</b> Address: <b>Deerfield, Ks. 67838</b>			
Locate with "X" in section below: N  W E S 1 Mile			Sketch map:			4 Well depth: <b>311</b> ft. Date of completion <b>4-19-75</b> Well diameter <b>26</b> in.
2 Type and color of material			From		To	
			See attached			
			<b>BROCK 3/2"</b>			
			4 Well depth: <b>311</b> ft. Date of completion <b>4-19-75</b> Well diameter <b>26</b> in.			
			5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
			6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>			
			7 Casing: Material <b>Steel</b> Height: <b>above</b> below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. Diam. Weight <b>36</b> lbs./ft. <b>16</b> in. to <b>311</b> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No ___ in. to ___ ft. depth			
			8 Screen: Manufacturer <b>Johnson</b> Type <b>Continuous</b> Dia. <b>16"</b> Slot/gauze <b>00&amp;150</b> Length <b>45'</b> Set between <b>175</b> ft. and <b>190</b> ft. <b>229&amp;309'</b> Fittings: <b>205 &amp; 225</b> Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <b>1/8</b>			
			9 Static water level: <b>129</b> ft. below land surface Date <b>1-30-75</b>			
			10 Pumping level below land surfaces: <b>172'</b> ft. after <b>2</b> hrs. pumping <b>1350</b> g.p.m. ___ ft. after ___ hrs. pumping ___ g.p.m. Estimated maximum yield ___ g.p.m.			
			11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ___			
			12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade			
			13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From <b>0</b> ft. to <b>10</b> ft.			
			14 Nearest source of possible contamination: <b>None Observed</b> ft. ___ Direction ___ Type ___ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
			15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <b>Floway</b> Model number <b>14DKH</b> HP ___ Volts ___ Length of drop pipe <b>245</b> ft. capacity <b>1350</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
16 Remarks: elevation  Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			<b>2991 (TOPO)</b>		17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Henkle Drilling &amp; Supply 145</b> Business name License No. Address <b>Box 639 Garden City, Ks.</b> Signed <b>Richard Henkle</b> <b>4/30/75</b> Authorized representative	

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

**DRILLERS TEST LOG**

CUSTOMERS NAME H20 DATE 1-20-75  
 STREET ADDRESS % Bob Landon TEST # 8 N.L.Hole 120  
 CITY & STATE Garden City, Kansas DRILLER Rector  
 COUNTY Finney QUARTER SW SECTION 31 TOWNSHIP 22 RANGE 24

LOCATION In SE corner of 4

**WELL LOCATION**

Static Water Level / 28'

%	DRILLED FOOTAGE		Description of Strata	Proposed Well Depth
	from	Pay to		
	0	3	Top soil	
	3	63	Brown sandy clay and fine sand	
	63	70	Sand and gravel med. coarse, small.	
	70	138	Brown clay and caliche	
45	138	170	Sand fine med. coarse, small gravel. Very few sandy clay st. Loose. Took water.	
65	170	225	Sand fine med. coarse; small coarse; med. to small gravel and few tiny white rock. Loose. Used lots of water. Good	
	225	235	Brown clay	
55	235	245	Sand fine med. coarse; small coarse, few med., small gravel. Loose. Used water.	
20	245	255	Brown clay, sand, med. coarse; med., small and broken white rock. Fairly loose. Used little water	
45	255	275	Sand, fine med. coarse, small coarse, few gravel. Sandy clay, used water.	
	275	299	Brown clay, soapstone and few sand st.	
65	299	309	Sand fine med. coarse, small coarse, small gravel Few, small white rock. Loose. Used lots of water.	
	309	312	Brown clay	
	312	320	Shale	
		137		
<b>TOTAL DEPTH OF WELL</b>				<b>311 Ft.</b>
<b>Set up facing east. Pit on the south.</b>				