

Sent 1/27/78

WOLF

WATER WELL RECORD
KSA 82a-1201-1215

DDDD

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

1. Location of well:	County Kearny	Fraction SE 1/4 SE 1/4 SE 1/4	Section number 26	Township number T 32 S R 35	Range number 35
2. Distance and direction from nearest town or city: 8 1/2 Mi. North of Deerfeld		3. Owner of well: Steenis & Morgan Inc.		City, state, zip code: Deerfeld, Kansas 67838	
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 26 in. Completion date _____ Well depth 210 ft. 8/2/76	
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
fine sand, clay		0	20	9. Casing: Material steel Height Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP _____ PVC _____ Weight 36.86 lbs./ft. Dia. 16 in. to 210 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 219	
clay		20	60	10. Screen: Manufacturer's name Lakewood Type Millplot Dia. 16" Slot/gauze 1/8 x 2 Length 81 Set between 129 ft. and 210 ft. ft. and _____ ft.	
sandy clay		60	100	Gravel pack? <input checked="" type="checkbox"/> YES Size range of material 1/2 x 3/4	
sand, gravel		100	120	11. Static water level: _____ mo./day/yr. 153 ft. below land surface Date 6/11/76	
sand, clay balls		120	140	12. Pumping level below land surfaces: 197 ft. after 10 hrs. pumping 780 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 780 g.p.m.	
med. to coarse sand (clean)		140	180	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____	
sand, gravel, little yellow clay		180	210	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade	
BROCK 208'				15. Well grouted? <input checked="" type="checkbox"/> yes With: _____ Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: ft. 250 Direction South Type corral Well disinfected upon completion? _____ Yes <input checked="" type="checkbox"/> No	
				17. Pump: _____ Not installed Manufacturer's name Worthington Model number 18-12M-75 HP _____ Volts _____ Length of drop pipe 200 ft. capacity 750 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.	
18. Elevation:	19. Remarks: 3021 (TOPO)		20. High Plains Drilling & Supply, Inc. 136 Business name License No. 402 North Third Garden City, Ka. 67846 Bob D. Haberman Date 8-30-76 Authorized representative		

T 32 S R 35 SE SE SE SE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5