


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County <b>Kearny</b>	Township name	Fraction <b>E 1/2 NW 1/2</b>	Section number <b>23</b>	Town number <b>22</b>	Range number <b>38</b>		
Distance and direction from nearest town or city: <b>12 mi west-12 1/2 mi north of Lakin, Ks.</b> Street address of well location if in city:				3 Owner of well: <b>High Plains Drilling &amp; Supply, Inc.</b> Address: <b>402 N 3rd, Garden City, Ks. 67846</b>				
Locate with "X" in section below: N  W E S 1 Mile				Sketch map: <b>316 ft E of Center pivot</b>		4 Well depth: <b>237</b> ft. Date of completion <b>3-31-75</b> Well diameter <b>26</b> in.		
2 Type and color of material				From	To	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				Clay		1	160	6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>
				Gravel		160	180	7 Casing: Material <b>steel</b> Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. Diam. Weight <b>1.88</b> lbs./ft. <b>16</b> in. to <b>237</b> ft. depth Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No ___ in. to ___ ft. depth
				Fine sand		180	200	8 Screen: Manufacturer <b>Mill slot</b> Type <b>6 %</b> Dia. <b>16"</b> Slot/gauze <b>1/8</b> Length <b>2"</b> Set between <b>175</b> ft. and <b>237</b> ft. Fittings: <b>1x 5/8</b> Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material ___
				Gravel		200	220	9 Static water level: <b>181</b> ft. below land surface Date <b>3-31-75</b>
				Sand fine light, shale		220	240	10 Pumping level below land surfaces: <b>188</b> ft. after <b>10</b> hrs. pumping <b>200</b> g.p.m. ___ ft. after ___ hrs. pumping ___ g.p.m. Estimated maximum yield <b>235</b> g.p.m.
								11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ___
								12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade
								13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> ___ Depth: From <b>0</b> ft. to <b>10</b> ft.
								14 Nearest source of possible contamination: ft. ___ Direction ___ Type <b>NA</b> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No
				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <b>Goulds</b> Model number <b>660131</b> HP ___ Volts ___ Length of drop pipe <b>231</b> ft. capacity <b>200</b> g.m.p. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				
16 Remarks: elevation  Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <b>Level</b> <input type="checkbox"/> Valley				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>High Plains Drilling Supply, Inc</b> Business name License No. ___ Address <b>402 N 3rd Garden City</b> Signed <b>Walter Blackman</b> Date <b>4-11-75</b> Authorized representative				