


sent 1/26/78

USE TYPEWRITER OR BALL POINT PEN - PRESS FIRMLY, PRINT CLEAR

WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment - Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County AMHILTON	Fraction SE 1/4 SE 1/4 SE 1/4	Section number 13	Township number T 22 S	Range number R 9 W
2. Distance and direction from nearest town or city: 13 miles north of Kendall west side of road <small>Street address of well location if in city:</small>				3. Owner of well: A.S. Gillam R.R. or street: Kendall, Ks. 67857 City, state, zip code:		
4. Locate with "X" in section below: 				Sketch map:		
5. Type and color of material				From	To	6. Bore hole dia. 10 in. Completion date 6-30-76 Well depth 258 ft.
						7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
						8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
						<input checked="" type="checkbox"/> Casing: Material Plastic Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 255 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gage No. 219
						10. Screen: Manufacturer's name _____ No Screen Type _____ Dia. _____ Slot/gauze _____ Length _____ Perf. 50 Set at the bottom _____ ft. _____ ft. and _____ 1/2" Down Gravel pack? yes Size range of material _____
						11. Static water level: _____ 219 ft. below land surface Date 8-17-76
						12. Pumping level below land surfaces: 219 ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.
						<input checked="" type="checkbox"/> Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input type="checkbox"/> No Date 6-30-76
						14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter _____ Inches above grade
						15. Well grouted yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
						16. Nearest source of possible contamination: _____ ft. _____ Direction _____ Type N/A Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: _____ Not installed Manufacturer's name Goulds US Pumps Model number 5ES 0512P 1/2 Volts _____ Length of drop pipe 214 ft. capacity 6 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 208 Business address: P.O. Box A Garden City, Ks. Address: _____ Signed: _____ Date 9-22-76 Authorized representative		

76
22 390 13
T
R
S
1/4 1/4 1/4
SESESE

MINTER-WILSON DRILLING CO. Company and Registered
INCORPORATED

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

A. S. Gillam
Hamilton County
6-17-75

Location: 13 miles north of Kendall, 20 west of trailer house. West side of road SE $\frac{1}{4}$ SE $\frac{1}{4}$ 13-22-39

0	2	Top soil
2	15	Brown, sandy clay
15	95	Fine to med. sand & gravel
95	106	Brown sandy clay
106	110	Fine to med. sand and gravel (hard spot)
110	140	Fine to med. sand & gravel (clay streak)
140	185	Med. sand & gravel, mixed white rock
185	191	Med. coarse gravel, white rock (tight)
191	220	Brown sandy clay
220	256	Med. sand gravel, mixed with white rock
256	260	Brown sandy clay

Static Water Level: 219'

House