

1 LOCATION OF WATER WELL
 County: Reno Fraction NE 1/4 SW 1/4 SE 1/4 Section Number 18 Township Number T 22 S Range Number R 5 E (W)

Distance and direction from nearest town or city? 3 mi N. 3/4 E of Hutchinson, KS Street address of well if located within city? 924 E 69th


2 WATER WELL OWNER: Robert Filbrick
 RR#, St. Address, Box #: 220 E 6th
 City, State, ZIP Code: Hutchinson, KS 67501
 Board of Agriculture, Division of Water Resources
 Application Number:

3 DEPTH OF COMPLETED WELL: 88 ft. Bore Hole Diameter: 1.0 in. to 88 ft., and in. to ft.
 Well Water to be used as:
 Domestic 3 Feedlot 5 Public water supply 8 Air conditioning 11 Injection well
 Irrigation 4 Industrial 6 Oil field water supply 9 Dewatering 12 Other (Specify below)
 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Observation well
 Well's static water level: 23 ft. below land surface measured on 7-4 month 28 day 80 year
 Pump Test Data: Well water was 34 ft. after 4 hours pumping. 20 gpm
 Est. Yield 40 gpm: Well water was ft. after hours pumping gpm

4 TYPE OF BLANK CASING USED:
 1 Steel 3 RMP (SR) 6 Asbestos-Cement 9 Other (specify below) Welded
 2 PVC 4 ABS 7 Fiberglass Threaded
 Blank casing dia: 6 in. to 68 ft., Dia in. to ft., Dia in. to ft.
 Casing height above land surface: 14 in., weight 3.35 lbs./ft. Wall thickness or gauge No: 160*
 TYPE OF SCREEN OR PERFORATION MATERIAL:
 1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 11 Other (specify)
 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole)
 Screen or Perforation Openings Are:
 1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole)
 2 Louvered shutter 4 Key punched 7 Torch cut 10 Other (specify)
 Screen-Perforation Dia: 6 in. to 88 ft., Dia in. to ft., Dia in. to ft.
 Screen-Perforated Intervals: From 68 ft. to 88 ft., From ft. to ft.
 Gravel Pack Intervals: From 60 ft. to 88 ft., From ft. to ft.

5 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other
 Grouted Intervals: From 4 ft. to 14 ft., From ft. to ft., From ft. to ft.
 What is the nearest source of possible contamination:
 1 Septic tank 4 Cess pool 7 Sewage lagoon 10 Fuel storage 14 Abandoned water well
 2 Sewer lines 5 Seepage pit 8 Feed yard 11 Fertilizer storage 15 Oil well/Gas well
 3 Lateral lines 6 Pit privy 9 Livestock pens 12 Insecticide storage 16 Other (specify below)
 13 Watertight sewer lines
 Direction from well: S.W., How many feet: 200 ? Water Well Disinfected? Yes No
 Was a chemical/bacteriological sample submitted to Department? Yes No If yes, date sample was submitted month day year
 Pump Installed? Yes No
 If Yes: Pump Manufacturer's name: Aermotor Model No. 5020 HP 3/4 Volts 230
 Depth of Pump Intake: 60 ft. Pumps Capacity rated at 25 gal./min.
 Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other

6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on 7 month 29 day 80 year
 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 382
 This Water Well Record was completed on 8 month 14 day 80 year under the business name of Miller Water Well Service by (signature) Egan Miller

7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:


FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
0	10	Dune Sand			
10	14	Br Clay			
14	25	Fine Br Sand			
25	32	F Gray Sand			
32	48	Gr Clay			
48	54	F Sand			
54	69	Br Clay			
69	83	F Gr Sand-layered Clay			
83	89	F-M Sand			
89	93	Light Br Clay			

 ELEVATION: clpland

Depth(s) Groundwater Encountered 1. 23 ft. 2. 48 ft. 3. 69 ft. 4. ft. (Use a second sheet if needed)

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.

OFFICE USE ONLY
T
R
SEC.
NE 1/4 SW 1/4 SE 1/4