86

Darling Drilling Co.

Residence Phone 662-3991

1211 W. 4th
Hutchinson, Kansas 67501

Office Phone 662-7901

DRILLER'S TEST LOG

Customer's Name: Conrad Eriksen Date: April 13,1973

Address: 421 Wickham Blvd. Manhattan,Kansas Test No.

County: Reno Quarter: N W ¼ Section: 3 Township: 22 Range: 9

DRILLED FOOTAGE From	To	DESCRIPTION OF STRATA
0	2	soil
2	25	fine sand
25	35	fine sand and clay
35	50	clay
50	60	sandy clay
60	70	fine to med sand
70	105	med. to coarse sand
105	106	shale

Indicate Test Location By an X

	X		

WATER TEST

Elec. Conductivity 510
Esti. Sodium 41.9 %
Total Hardness 8.2 Gr/Gal
Salt (Sodium Chloride) 120 ppm

Static Water Level: 37ft.

REMARKS: Estimate 700 to 800 GPM

Donald J Darling