


USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County HARVEY	Township name MACON	Fraction SE 1/4 / SW 1/4	Section number 3	Town number T-23-5	Range number R-1-W	
Distance and direction from nearest town or city: 4 miles - west of Newton				3 Owner of well: LOREN D PENNER			
Street address of well location if in city:				Address: #8 Circle Drive, Newton, KNS			
Locate with "X" in section below: N  S 1 Mile		Sketch map:		4 Well depth: 50 ft. Date of completion 4/14/75 Well diameter 6 in. bone 14"			
2		Type and color of material	From	To	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
		0-5 loam to red clay			6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
		5-13 reddish-brown clay			7 Casing: Material PVC Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 6" Weight 3.10 lbs./ft. + 12 in. to 50 ft. depth Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No		
		13-18 Sandy clay			8 Screen: Manufacturer own - pipe - cut - tool Type PVC Dia. 6" Slot/gauze 1/8 Length 20' Set between 15 ft. and 35 ft. Fittings: 1 1/2" - 1/2" Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/8" - 1/2"		
		18-34 Sand - medium			9 Static water level: 16' ft. below land surface Date 4/14/75		
		w several thin white shale layers			10 Pumping level below land surfaces: 16' ft. after 1 hrs. pumping 80 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 40 g.p.m.		
		34-39 White lime rock			11 Water sample submitted: water analysis run + <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date 15 available		
		39-41 green-grey - soft shale			12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter inches above grade		
		41-45 Sand coarse			13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 15 ft. to 3 ft.		
		45-46 green shale			14 Nearest source of possible contamination: house ft. 38' Direction South Type Sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
		46-48 " " to grey			15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		48-50 dark shale (Wellington)			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. PAUL'S INC 175 Business name _____ License No. _____ Address Box 26 - Heaton Signed Paul Bamber Date 4/14/75 Authorized representative		
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley (use a second sheet if needed)							