

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County HARVEY	Township name MACON	Fraction NE 1/4 NE 1/4	Section number 10	Town number T-23-S	Range number R-1-W
Distance and direction from nearest town or city:				3 Owner of well: BILL MOORE		
Street address of well location if in city:				Address: R.R. #1 - NEWTON		
Locate with "X" in section below: N		Sketch map:		4 Well depth: 48 ft. Date of completion 8/12/75 Well diameter 12 in.		
		5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry		
				<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
		7 Casing: Material PVC Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 24 in. Diam. 6 in. to 48 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Weight 3.33 lbs./ft.		8 Screen:		
				Manufacturer Cert-tel - Ann Arbor Type PVC Dia. 6" Slot/gauze .0468 Length 15' Set between 38 ft. and 30 + 18 = 25 Fittings: 1/8" - 1/4" Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material		
		9 Static water level: 10 ft. below land surface Date 8/12/75		10 Pumping level below land surfaces:		
				48 ft. after 1 hrs. pumping 870 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 8-10 g.p.m.		
		11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		12 Well head completion:		
				<input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
		13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 10 ft. to 0 ft.		14 Nearest source of possible contamination:		
				ft. 600 Direction NE Type Gravel Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
		15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Dempster Model number D-H-30 HP 1/3 Volts 230 Length of drop pipe 40 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		17 Water well contractor's certification:		
				This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. PAUL'S INC 175 Business name License No. Address 216 HESSTON Signed Paul Budz Date 8/12/75 Authorized representative		
16 Remarks: elevation						
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						