

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County HARVEY	Fraction NE 1/4 SE 1/4 SE 1/4	Section number 10	Township number T -23-S	Range number S R 1 EW
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: MIKE EVANS R.R. or street: 706 SPRUCE City, state, zip code: HALSTEED KANSAS			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 13 in. Completion date 10/22/75 Well depth 85 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From	To	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 3.22 lbs./ft. Dia. 6 in. to 35 ft. depth Wall Thickness: inches or Dia. 0 in. to 85 ft. depth gage No. e255		
SANDY loam		0	5	10. Screen: Manufacturer's name CERT-TEC - own slot Type PVC Dia. 6" Slot/gauze .0468 Length 10" Set between 25 ft. and 35 ft. ft. and ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 10-14		
loam to sandy clay		5	10	11. Static water level: mo./day/yr. 4 ft. below land surface Date 10/22/75		
SAND - brown		10	15	12. Pumping level below land surfaces: 48 ft. after 1 hrs. pumping 15 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 15 g.p.m.		
clay brownish red		15	22	13. Water sample submitted: mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 10/24/75		
ALKALI - clay		22	25	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
SANDY white clay		25	28	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 10 ft. to 0 ft.		
SAND - Med to coarse w/ clay mixed		28	33	16. Nearest source of possible contamination: ft. 50 Direction WEST Type pasture Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
green shale to grey shale		33	35	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name ARMSTRONG Model number SD-12-50HP 1/2 Volts 230 Length of drop pipe 75 ft. capacity 12 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
grey shale to dark		35	38	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. PAUL'S INC # 175 Business name License No. Address 400 N LANCASTER Signed Paul Brunk Date 10/24/75 Authorized representative		
dark "Wellington" shale		38	85			
(Use a second sheet if needed)						
18. Elevation:	19. Remarks: CASED TO 35' - open hole (53 1/4") below -					
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5