

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Harvey	Fraction N 1/4 of SW 1/4	Section number 11	Township number T 23 S	Range number R 1 W	E/W
2. Distance and direction from nearest town or city: 1 1/4 mile N of Meridian		3. Owner of well: Arnold Nye		R.R. or street: Moorklands West-Newton			
4. Locate with "X" in section below: <div style="text-align: center;">N 1 Mile W E S 1 Mile</div>		Sketch map: 		6. Bore hole dia. 10-8 in. Completion date Well depth 56 ft. 3-20-77			
5. Type and color of material				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
				9. Casing: Material Plastic Height Above or below NLC Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 14 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 200 lbs./ft. Dia. 5 in. to 56 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 210			
				10. Screen: Manufacturer's name Sunflow Plastic 1/4 in. Type RMP Dia. 5 Slot/gauze 3/32 Length 25 Set between 20 ft. and 30 ft. 36 ft. and 51 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8-1/4			
				11. Static water level: <input type="checkbox"/> mo./day/yr. 11 ft. below land surface Date Mar 23 77			
				12. Pumping level below land surfaces: 11 ft. after 20 hrs. pumping 20 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 15 g.p.m.			
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>			
				14. Well head completion: <input type="checkbox"/> Pitless adapter 14 Inches above grade			
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From top ft. to 10 ft.			
				16. Nearest source of possible contamination: ft. 400 Direction NW Type crack Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input checked="" type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Terence Budala 221 Business name R4 Newton License No. <input type="checkbox"/> Address 5497 Signed Terence Budala Date 5/9/77 Authorized representative			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5