


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Harvey	Fraction SW 1/4 SW 1/4 NW 1/4	Section number 21	Township number T 23 S	Range number R 1W E (W)	
2. Distance and direction from nearest town or city: 1 West and 1/2 North of Hyway 50 and Ridge Rd. Street address of well location if in city: Halstead, Kansas				3. Owner of well: Weldon Wenger R.R. or street: RFD 1 Newton, Kansas City, state, zip code: Halstead, Kansas			
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile		Sketch map: 		6. Bore hole dia. 30 in. Completion date 5-11-77 Well depth 100 ft.			
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
Red Clay		0	30	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
Gray Clay		30	40	9. Casing: Material Transite Height: Above or below See #19 Threading Welded Surface 12 in. RMP PVC Weight 37 lbs./ft. Dia. 16 in. to 100 ft. depth Wall Thickness: inches or Dia. 16 in. to 100 ft. depth gauge No. 3/4"			
				10. Screen: Manufacturer's name Johnson Type Irrigator Dia. 16" Slot/gauze .100 Length 25' Set between 75 ft. and 100 ft. ft. and 100 ft. Gravel pack? yes Size range of material 1/2-1/8"			
				11. Static water level: 28 ft. below land surface Date 5-11-77 mo./day/yr.			
				12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.			
				13. Water sample submitted: mo./day/yr. Yes No Date			
				14. Well head completion: 12 inches above grade Pitless adapter			
				15. Well grouted? yes to 2 fine sand mix With: Neat cement Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
				16. Nearest source of possible contamination: NONE ft. Direction Type Well disinfected upon completion? <input checked="" type="checkbox"/> Yes No			
				17. Pump: Not installed Manufacturer's name Simmons Model number 6S-1000 HP 60 Volts 460 Length of drop pipe 80 ft. capacity 500 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
		(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: Flat Ground From #9 Banded But Joint No apparent source for contamination.				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name License No. Address Wichi ta, Kansas Signed M. Arnold Date 9-8-77 Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5