

1. Location of well:		County <b>HARVEY</b>	Fraction <b>SE 1/4 SW 1/4 SW 1/4</b>	Section number <b>22</b>	Township number <b>T 23-S</b>	Range number <b>S R 1 E</b>
2. Distance and direction from nearest town or city: Street address of well location if in city:		<b>2 3/4 mile west of NEWTON - Hwy 50</b>		3. Owner of well: R.R. or street: City, state, zip code:		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <b>12</b> in. Completion date Well depth <b>54</b> ft. <b>4/23/76</b>		
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From		To		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
top loam		0		2		9. Casing: Material <b>plastic</b> Height: <b>Above</b> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <b>3.22</b> lbs./ft. Dia. <b>6</b> in. to <b>54</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. <b>235</b>
alkali & clay		2		6		10. Screen: Manufacturer's name <b>Cert-tec</b> Type <b>PVC</b> Dia. <b>6</b> in. Slot/gauge <b>0.064</b> Length <b>20</b> ft. Set between <b>34</b> ft. and <b>54</b> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <b>10-14</b>
brown clay		6		17		11. Static water level: <b>21</b> ft. below land surface Date <b>4/23/76</b>
small fine sand		17		19		12. Pumping level below land surfaces: <b>35</b> ft. after <b>2</b> hrs. pumping <b>20</b> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <b>20</b> g.p.m.
brown clay		19		48		13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date <b>4/23/76</b>
MEDIUM TO COARSE SAND		48		53		14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> _____ inches above grade
GREEN-GRAY SHALE		53		54		15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.
						16. Nearest source of possible contamination: <b>plastic</b> ft. <b>18</b> Direction <b>North</b> Type <b>saw</b> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: Manufacturer's name <b>VALLEY</b> Not installed Model number <b>SIBOS PMP 500</b> <b>-1/2 hp.</b> Volts <b>230</b> Length of drop pipe <b>50</b> ft. capacity <b>18</b> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input checked="" type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		<b>Owner To pour 4' slab around well</b>		<b>PAUL'S INC 175</b> Business name License No. Address <b>HESSTON, KNS</b> Signed <b>Paul Bustert</b> Date <b>4/24</b> Authorized representative		