


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County HARVEY	Fraction NE 1/4 NE 1/4 SE 1/4	Section number 24	Township number T 23 S	Range number R 1-W E/W
2. Distance and direction from nearest town or city:			3. Owner of well: JAMES CALLAWAY		
Street address of well location if in city: 405 S. MERIDIAN			R.R. or street: 508 ROLLING HILLS DRIVE		
			City, state, zip code: NEWTON KANS 67114		
4. Locate with "X" in section below: <div style="text-align: center;">N 1 Mile W  E S 1 Mile</div>			6. Bore hole dia. 10 in. Completion date 5-15-79 Well depth 53 ft.		
			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material PLAST Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 33 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. 200		
5. Type and color of material			From	To	10. Screen: Manufacturer's name SCUMFLOWER PLAST PIPE
CLAY			0	40	Type 200 Dia. 5
COARSE GRAVEL			40	50	Slot/gauze SLOT 1/16 Length 201
SHALE			50	53	Set between 33 ft. and 53 ft.
					Gravel pack? YES Size range of material 1/8" 1/4"
					11. Static water level: 14 ft. below land surface Date 5-15-79
					12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 10 g.p.m.
					13. Water sample submitted: ____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____
					14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter ____ inches above grade
					15. Well grouted? YES With: ____ Neat cement ____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.
					16. Nearest source of possible contamination: ft. 400' Direction EAST Type LAGOON Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input type="checkbox"/> Not installed Manufacturer's name GLAXES Model number DE 105112 HP 1/2 Volts 230 Length of drop pipe 40 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
			(Use a second sheet if needed)		
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. MARTIN Supply 362 Business name 500 W JAMP N NEWTON License No. 1/4 NE NE 6 SE Address 500 W JAMP N NEWTON Signed Dutch Arnold Date 5-18-79 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					