

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Rec'd Smith
12/28/77
#4 Northwood &

1. Location of well:		County: HARVEY	Fraction: NE 1/4 NW 1/4 SW 1/4	Section number: 24	Township number: T 23 S	Range number: R 1 W
2. Distance and direction from nearest town or city:			3. Owner of well: Smada Enterprises			
Street address of well location if in city: #4 Northwood Ct. Newton			P.R. or street: Box 704 Newton KS 67114			
4. Locate with "X" in section below:			Sketch map:			
5. Type and color of material			From	To	6. Bore hole dia. 6 in. Completion date: 4/28/77	
Top soil.			0	4	Well depth 80 ft.	
black clay.			4	24	7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug	
fine sand.			24	25	<input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
black shale.			25	80	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry	
(Steelman well)					<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock	
On 1-11-78 this well was forced through with 500g of concentrated H ₂ O (500 mg/l solution mixed) vent was also installed					<input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material PVC Height: Above or below	
					Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 3 in.	
					RMP 3 PVC Weight 19.6 lbs./ft.	
					Dia. 3 in. to 80 ft. depth Wall Thickness: inches or	
					Dia. 3 in. to 80 ft. depth gage No. 115	
					10. Screen: Manufacturer's name MPT	
					Type PVC Dia. 3 in.	
					Slot/gauge 1/16 Length 30 ft.	
					Set between 30 ft. and 80 ft.	
					Gravel pack? yes Size range of material 3/8	
					11. Static water level: 30 ft. below land surface Date 11/25/77	
					12. Pumping level below land surfaces:	
					60 ft. after 12 hrs. pumping 10 g.p.m.	
					12 ft. after 12 hrs. pumping 10 g.p.m.	
					Estimated maximum yield 12 g.p.m.	
					13. Water sample submitted: yes mo./day/yr.	
					14. Well head completion: 12 inches above grade	
					X Pitless adapter 12 inches above grade	
					15. Well grouted? yes	
					With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete	
					Depth: From 3 ft. to 13 ft.	
					16. Nearest source of possible contamination:	
					ft. none Direction none Type none	
					Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: Not installed	
					Manufacturer's name McDonald	
					Model number 1204 HP 1/2 Volts 220	
					Length of drop pipe 70 ft. capacity 12 g.p.m.	
					Type:	
					<input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine	
					<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating	
					<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:		19. Remarks: Contractor to furnish 4x4x4 slab around casing & comply with State Regulations				
Topography:		Signed [Signature] 2/1/78				
<input type="checkbox"/> Hill		20. Water well contractor's certification:				
<input type="checkbox"/> Slope		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.				
<input checked="" type="checkbox"/> Upland		Business name Wm. H. Bulley License No. 318				
<input type="checkbox"/> Valley		Address Colwich				
		Signed [Signature] 11/25/77				
		Authorized representative				

23 - 10 24 NE 1/4 SW 1/4