


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County HARVEY	Fraction NE 1/4 NW 1/4 SW 1/4	Section number 24	Township number T 23 S	Range number R 1 E
2. Distance and direction from nearest town or city:		3. Owner of well: BERNIE WANDRA				
Street address of well location if in city:		R.R. or street: 322 Harrison St.				
		City, state, zip code: Newton, KS 67114				
4. Locate with "X" in section below:		Sketch map:				6. Bore hole dia. 11 in. Completion date 8/17/78
						Well depth 93 ft.
						7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
						8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
						9. Casing: Material plastic Height: Above or below 36" in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 36" in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2.82 lbs./ft. Dia. 5 in. to 93 ft. depth Wall Thickness: inches or 258 gage No. 258
5. Type and color of material		From		To		10. Screen: Manufacturer's name pumpco
SILTY LOAM		0		5		Type pvc Dia. 5"
SILTY SAND		5		8		Slot/gauze 1020 Length 15'
BROWN CLAY - gritty		8		16		Set between 19 ft. and 24 ft.
SANDY CLAY		16		19		90 ft. and 80 ft.
SAND / CLAY MIXED - loose		19		23		Gravel pack? <input checked="" type="checkbox"/> Size range of material 18-24
GREEN GREY SHALE		23		25		11. Static water level: 8' ft. below land surface Date 8/17/78
GREY SHALE to DARK		25		30		12. Pumping level below land surfaces: 75 ft. after 8 hrs. pumping 10 g.p.m.
DARK SHALE		30		45		Estimated maximum yield 10/12 g.p.m.
" "		45		53		13. Water sample submitted: X Yes <input checked="" type="checkbox"/> No Date
HARD LIME ROCK		53		55		14. Well head completion: X Pitless adapter 36 inches above grade
DARK SHALE		55		64		15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete
" "		64		82		Depth: From 12 ft. to 0 ft.
" "		82		93		16. Nearest source of possible contamination: 30 ft. Direction SE Type creek
						Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: <input checked="" type="checkbox"/> Not installed
						Manufacturer's name
						Model number HP Volts
						Length of drop pipe ft. capacity g.p.m.
						Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography:		Small faults at		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
<input type="checkbox"/> Hill		45'		PAUL'S INC #125		
<input type="checkbox"/> Slope		64'		Business name HESSON, KS - Box 24		
<input type="checkbox"/> Upland		82'		Address Newton, KS		
<input type="checkbox"/> Valley				Signed Paul Baulant Date 8/17/78		

23 - 10 24 NE NW SW
T R Sec 1/4 1/4 1/4