

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County HARVEY	Fraction NW 1/4 SW 1/4 SW 1/4	Section number 24	Township number T 23 S R 1 E	Range number EW
2. Distance and direction from nearest town or city: Street address of well location if in city:		3. Owner of well: R.R. or street:		City, state, zip code:		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile		Sketch map: house garage Sewer line R.R.		6. Bore hole dia. _____ in. Completion date _____ Well depth _____ ft. 5-16-77		
5. Type and color of material		From	To	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Learn - sandy		0	7	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Sand - surface (dune brown)		7	9	9. Casing: Material plastic Height: above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 12" in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 6.3 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 225		
green grey shale layered		9	20	10. Screen: Manufacturer's name _____ Robin Tech - own slot Type pvc Dia. 5" Slot/gauze .046 Length 20' Set between 23 ft. and 43 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4-1/2		
dark shale (Wellington)		20	25	11. Static water level: _____ mo./day/yr. 15 ft. below land surface Date 5-16-77		
" " (fault at 39')		25	39	12. Pumping level below land surfaces: 58 ft. after 1 hrs. pumping 10 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 8-10 g.p.m.		
" "		40	49	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
grey hard (flint rock) ! hard		49	51	14. Well head completion: _____ Pitless adapter 18 Inches above grade		
dark Wellington shale		51	58	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From 20 ft. to 3' ft.		
white hard lime rock		58	59	16. Nearest source of possible contamination: ft. 28 Direction EAST Type Sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No _____		
Wellington dark shale		59	88	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: _____ Submersible _____ Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other _____		
(Use a second sheet if needed)				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. PAUL'S INC #175 Business name _____ License No. _____ Address Box 26 Hesston KANS Signed Paul Burlant Date 5/16/77 Authorized representative		
18. Elevation: Topography: _____ Hill _____ Slope _____ Upland _____ Valley	19. Remarks: *1. Well cased & drilled to 63' 2. Test hole was to 88' 3. Variance was granted by county re prop. line & sewer line dist.					

23 Line
R - 100
24
1/4 1/4 NW SW SW