


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County HARVEY	Fraction SW 1/4 NW 1/4 SW 1/4	Section number 24	Township number T 23 S R 1	Range number 1
2. Distance and direction from nearest town or city: Royer Addition West		3. Owner of well: Gary Royer		R. or street: 1603 TERRACE AVE.		
Street address of well location if in city: LOT 20 BLK 20 Royer Addition West		City, state, zip code: NEWTON KS 67114				
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 11 in. Completion date 8/16/78 Well depth 66 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From		To		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Top Soil.		0		3		9. Casing: Material Styrene Height Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP 5 PVC Weight 1.50 lbs./ft. Dia. 5 in. to 66 ft. depth Wall Thickness: inches or Dia. 5 in. to 66 ft. depth gage No. 200
black clay.		3		11		10. Screen: Manufacturer's name Sunflower Type 200 Dia. 5 in. Slot gauge 1/16 Length 40 ft. Set between 26 ft. and 66 ft. Gravel pack yes Size range of material 3/8 in.
fine sand.		11		21		11. Static water level: 22 ft. below land surface Date 8/15/78
charcoal shale.		21		66		12. Pumping level below land surfaces: 40 ft. after 12 hrs. pumping 15 g.p.m. ft. after 12 hrs. pumping 15 g.p.m. Estimated maximum yield 20-25 g.p.m.
						13. Water sample submitted: no./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date
						14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade
						15. Well grouted? yes. With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.
						16. Nearest source of possible contamination: Main Sewer ft. 50 Direction NW Type June Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: Not installed Manufacturer's name FWW Model number 12518 HP 1/2 Vol. 230 Length of drop pipe 35 ft. Capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		Customer to furnish 4'x4'x4" slab at grade around well per State Regulations Signed X Nera Sn Higuera		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Wm. Miller 318 Business name Colowich KS License No. Address 8/20/78 Signed Wm. Miller Authorizing representative		

2-33-78
T 23 S R 1
1/4 1/4 1/4
SW NW SW