

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County HARVEY	Fraction NW 1/4 SW 1/4 NW 1/4	Section number 26	Township number T 23 S	Range number R 1-W E/W
2. Distance and direction from nearest town or city: 1 1/2 miles WEST ON U.S. 50 1/4 - SOUTH Street address of well location if in city:			3. Owner of well: OTTO QUIRING R.R. or street: RR #1 City, state, zip code: NEWTON KANS 67114		
4. Locate with "X" in section below: N W E S 1 Mile Sketch map:			6. Bore hole dia. 10 in. Completion date 5-30-79 Well depth 60 ft.		
5. Type and color of material			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material PAAS Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 30 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 40 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 200		
			10. Screen: Manufacturer's name SCHEFFELER PLAST. PIPE Type 200 Dia. 5 1/2 Slot gauge 1/16 Length 20 Set between 40 ft. and 60 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? YES Size range of material 1/8 - 1/4		
			11. Static water level: <input type="checkbox"/> mo./day/yr. 14 ft. below land surface Date 5-3-79		
12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 10 g.p.m.			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
14. Well head completion: <input type="checkbox"/> Pitless adapter 30 Inches above grade			15. Well grouted? YES With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 12 ft.		
16. Nearest source of possible contamination: ft. 100 Direction W Type GRAVEL DITCH Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. MARTIN SUPPLY 362 Business name License No. Address 500 W. 10th N. NEWTON Signed Glenn Schmitt Date 6-3-79 Authorized Representative		
19. Remarks:					

(Use a second sheet if needed)

Topography:
☐ Hill
☐ Slope
☒ Upland
☐ Valley