


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County <b>Harvey</b>	Township name	Fraction <b>NW4-SW4</b>	Section number <b>32</b>	Town number <b>T-23-S</b>	Range number <b>R-1-W</b>	
Distance and direction from nearest town or city:			3 Owner of well: <b>City Water Department City of Newton Newton, Kansas</b>				
Street address of well location if in city:			Address:				
Locate with "X" in section below: N 			Sketch map: <b>Well No. 16</b>		4 Well depth: <u>134</u> ft. Date of completion <u>8/5/75</u> Well diameter <u>38</u> in.		
2 Type and color of material			From		To		5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
							6 Use: <input type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>
							7 Casing: Material <u>Stl</u> Height: above <u>SSW</u> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>36</u> in. Diam. <u>12</u> in. to <u>94</u> ft. depth Weight <u>34</u> lbs./ft. Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
							8 Screen: Manufacturer <u>Layne</u> Type <u>St. Stl.</u> Dia. <u>12"</u> Slot/gauze <u>0.105"</u> Length <u>40'</u> Set between <u>65</u> ft. and <u>134</u> ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>1/8-3/8"</u>
Top soil			0		1		9 Static water level: <u>36.90</u> ft. below land surface Date <u>8/4/75</u>
Brown silt - sandy			1		11		10 Pumping level below land surfaces: <u>58.9</u> ft. after <u>3 1/2</u> hrs. pumping <u>536</u> g.p.m. <u>60.1</u> ft. after <u>6</u> hrs. pumping <u>656</u> g.p.m. Estimated maximum yield <u>750</u> g.p.m.
Med. to coarse sand & med. gravel			11		20		11 Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date <u>8/4/75</u>
Clay			20		50		12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade
Fine to coarse sand & fine to med. gravel			50		59		13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From <u>0</u> ft. to <u>22</u> ft.
Clay			59		61		14 Nearest source of possible contamination: ft. <u>1800</u> Direction <u>NE</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Fine to coarse sand & fine-med. gravel			61		68		15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Layne</u> Model number <u>10RK</u> HP <u>20</u> Volts <u>460</u> Length of drop pipe <u>80</u> ft. capacity <u>500</u> g.m.p. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Clay			68		72		17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Layne Western Co. 102</b> Business name License No. Address <u>Wichita, Kansas</u> Signed <u>[Signature]</u> Date <u>8/5/75</u>
Med. to coarse sand & fine-med. gravel			72		88		
Clay			88		104		
Med. to coarse sand & gravel			104		110		
Clay			110		117		
Med. to coarse sand & gravel			117		131		
Blue shale			131		134		
(use a second sheet if needed)							
16 Remarks: elevation  Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley							